





Securing our water. together.

Our ref: ME/11/0017

14 February 2011

Peter Borrows
Chief Executive Officer
Seqwater
PO Box 16146
City East QLD 4002




Dear Mr ~~Borrows~~

On 20 January 2011, the Honourable Stephen Robertson MP, Minister for Natural Resources, Mines and Energy and Minister for Trade, wrote to the Queensland Water Commission (Commission) requesting the Commission provide all necessary assistance to Seqwater to ensure the Minister's requests to Mr Phil Hennessy, Chair, Seqwater, as raised in his letter of 20 January 2011, are able to be responded to as a matter of priority and with urgency.

On 25 January 2011, the Commission advised the Minister that it was liaising with Seqwater and undertaking preliminary work to support the matters raised.

Since that time the Commission has progressed its work in order to be in a position to provide advice to Seqwater and/or the Minister as and when required.

On 4 February 2011, you provided us with a copy of a letter from Seqwater's Chair to Minister Robertson regarding Seqwater's consideration of the appropriate Full Supply Levels (FSL) for Wivenhoe and Somerset Dams. This letter advised that "DERM may be satisfied, based on advice from QWC and the WGM from a water supply security perspective, that Wivenhoe Dam's FSL could be reduced in the short term to, say, 75% of its current FSL".

I note that the South East Queensland (SEQ) Water Grid Manager has provided you with a letter on 9 February 2011, confirming that "from a water security perspective, the SEQ Water Grid Manager has no objection to Wivenhoe Dam being drawn down to 75% of its FSL".

As you are aware, the Commission has now finalised a draft report as input information material for Seqwater, as requested by the Minister (attached), titled *Impacts on SEQ Water Strategy of Various Operating Scenarios for Wivenhoe Dam, 14 February 2011, Version 6*. The purpose of this report is to provide information on the potential impact on the security of supply in SEQ if a significant volume of water is released from the water supply capacity of Wivenhoe Dam as a potential flood mitigation measure. The information in this report has been shared with Seqwater officers during the course of its preparation, and a full version provided to you on 12 February 2011.

In preparing this report, the Commission has based its assumptions on the SEQ Water Strategy of July 2010, including the addition of purified recycled water into Wivenhoe at the 40% trigger level. Demand forecasts have been updated to align with the recent bulk water price review in November 2010.

Queensland Water Commission
PO Box 15087 City East Qld 4002

Ph: +61 7 3227 8207 Fax: +61 7 3227 8227

ABN: 65 242 908 036 web: www.qwc.qld.gov.au

The report has considered scenarios as temporary options for the 2011 wet season, and commenced consideration of scenarios contemplating any permanent reductions to FSL from a Level of Service (LOS) yield perspective.

In summary, the report concludes that:

- If releases were made as a temporary measure to reduce the water level in Wivenhoe Dam by 25% from its FSL (a release of about 291,250 ML), the Risk Criteria of the *South East Queensland System Operating Plan* would still be met.
- Despite the above being met, if inflows for the next six years were as low as the 2001-2006 drought, full desalination may be triggered, as Grid 12 storage levels could drop to 60% in this time.
- As the volume released increases, more factors become impacted such as the increased likelihood of triggering desalination and the use of purified recycled water and restrictions, and potentially increased operating costs of the grid.
- Permanent reduction of the FSL by 25% will lower the LOS yield by about 30,000 ML/annum. This reduction in LOS yield may require the construction of new infrastructure to be brought forward by about five years to 2021, based on current demand assumptions. Other options to mitigate the yield reduction such as demand management measures may also be possible.
- Given the current demand is less than that in the recent bulk water price review assumptions used in this assessment, there is more confidence in the margin of supply security available in the demand/supply balance.
- Any permanent reduction would have to be more critically investigated, with this report commencing the analysis for purposes of assisting to inform the annual update of the SEQ Water Strategy and investigations related to the Brisbane River system.

Given the announcement on 13 February 2011 to lower the FSL to 75% for the 2011 wet season, the Commission looks forward to working with you closely in relation to any consideration of a permanent reduction of Wivenhoe's FSL.

The Commission would appreciate your feedback on this draft report, prior to formally progressing it as a final report to Seqwater and the Minister. I will be in touch shortly in order to discuss timing for your feedback with the aim of finalising the report within the next week or so.

If you require any further information, please contact me on [REDACTED] or on email at [REDACTED]

Yours sincerely

[REDACTED]
Karen Waldman
Chief Executive Officer

Enc (1)

cc John Bradley, Director General, Department of Environment and Resource Management

Barry Dennien, Chief Executive Officer, SEQ Water Grid Manager

INFORMATION MATERIAL ONLY



**Impacts on SEQ Water Strategy of
Various Operating Scenarios for
Wivenhoe Dam**

14 February 2011

Version 6

QWC

INFORMATION MATERIAL ONLY

Document Control

Date	Author/Reviewer	Description	Version
3/2/2011	Wai-Tong Wong	Draft	1
3/2/2011	Julie Allan, Mark Askins Richard Scott, Wendy Auton Justin Claridge, Gayle Leaver	Reviewed Draft - with edits	1, 2, 2A
8/2/2011	Wai-Tong Wong Mark Askins Wendy Auton	Draft edited with additional sections on modelling review by DERM, demand reduction and Waspp simulations. Incorporated comments by Karen Waldman	3
9/2/2011	Wai-Tong Wong Julie Allan, Mark Askins Wendy Auton, Justin Claridge John Collins (John Collins Consultants Pty Ltd)	Executive Summary added and section 4.1 edited. Comments from John Collins incorporated.	4
10/2/2011	Wai-Tong Wong Mark Askins, Wendy Auton Justin Claridge, Richard Scott	Incorporated strategic comments from Project Team meeting (Karen Waldman and Tad Bagdon)	5
11/2/2011	Wai-Tong Wong Julie Allan Mark Askins Justin Claridge	Incorporated minor edits and improved formatting	6

Approval

Date	Name	Description	Version
3/2/2011	Tad Bagdon Gayle Leaver	Reviewed	2
3/2/2011	Tad Bagdon Karen Waldman	Reviewed	2A
11/2/2011	Tad Bagdon Gayle Leaver Karen Waldman	Reviewed	5
11/2/2011	Tad Bagdon Karen Waldman	Reviewed	6

Table of Contents

1 Purpose	2
2 Background.....	2
3 Role of Queensland Water Commission	2
3.1 Background/Context	2
3.2 Report to Seqwater.....	3
4 Short Term Impacts	4
4.1 Use the SEQ Regional Water Balance Model (Wathnet Model) to assess the SOP risk criteria.....	4
4.2 Forecast the probability of Grid 12 storage levels over the next 5 years	6
4.3 Simulated storage behaviour of Grid 12 storages over the next 6 years for three inflow scenarios (using Waspp Model).....	8
5 Long Term Impacts - assessment of the potential impact on the LOS Yield (using Wathnet Model).....	10
5.1 Results – 10% reduction on Full Supply Volume for Wivenhoe Dam.....	10
5.2 Results – 25% reduction on Full Supply Volume for Wivenhoe Dam.....	10
5.3 Potential for demand reduction	11
6 Implications of each scenario.....	12
7 Peer review of modelling by Department of Environment and Resource Management.....	14
Appendix A – Level of Service Objectives (SEQ Water Strategy).....	15
Appendix B - Grid 12 Storages in South East Queensland.....	16
Appendix C – Wivenhoe Dam Storage Capacity Data	17

Executive Summary

The purpose of this report is to provide information on the potential impact on the security of supply in South East Queensland (SEQ) if a significant volume of water is released from the water supply capacity of Wivenhoe Dam as a potential flood mitigation measure.

In the main the scenarios considered would be potentially a temporary measure over the 2011 wet season, based on the impacts to the SEQ Water Grid as a whole. The underlying assumptions used include the demand and supply capacity contained in the SEQ Water Strategy, with demand forecasts updated to align with the recent bulk water price review in November 2010.

For completeness two scenarios involving permanent reduction in the full supply volume of Wivenhoe Dam have also been considered, but further investigation is required to understand the full impacts. This assessment is based on sensitivity analysis of the total grid capacity and no detailed assessment has been undertaken.

The following observations can be drawn from these assessments:

- If releases were made as a temporary measure to reduce the water level in Wivenhoe Dam by 25% of full supply capacity (a release of about 291,250 ML), the (five year) Risk Criteria of the SEQ System Operating Plan (SOP) would still be met.
- Despite the SOP Risk Criteria being met, if inflows for the next 6 years were as low as the 2001-2006 drought, full desalination production may be triggered, as Grid 12 storage levels could drop to 60% in this time.
- As the volume released increases, more factors become impacted such as the increased likelihood of triggering desalination and the use of purified recycled water and restrictions and potentially increased operating costs of the grid.
- Permanent reduction in the full supply volume of 25% will lower the LOS yield by about 30,000 ML/annum. This reduction in LOS yield may require the construction of new infrastructure to be brought forward by about 5 years to 2021, based on current demand assumptions. Other options to mitigate the yield reduction such as demand management measures may also be possible.

These analyses are an exercise in assessing risk management rather than a forecast for the future. Therefore an understanding of the consequences involved for a particular risk profile is important.

This report does not recommend a particular scenario for adoption as other factors such as social, economic and environmental may also need to be considered. It provides some risk information on the security of supply based on the short term (SOP Risk Criteria) and the long term water demand/supply balance in the SEQ Water Strategy.

Operational and regulatory impacts such as increased pumping costs and the Water Resource Plan have not been assessed. Advice from the responsible agency or entity would need to also be considered.

1 Purpose

The purpose of this report is to outline the results of the assessment, from a water supply security perspective for South East Queensland (SEQ) over the short and long term, of possible scenarios for lowering of Wivenhoe Dam below the current deemed full operating supply level (i.e. 100 percent dam level for water supply purposes). The effects of temporarily lowering the full supply level of Baroon Pocket and Hinze Dams were also assessed.

For the purpose of this report, short term is defined as the period over the next 5 years (as per risk criteria of SEQ System Operating Plan) where the supply security in SEQ may be impacted by any proposed temporary lowering of the Wivenhoe Dam operating level over the 2011 wet season.

Long term is defined as a period of up to 50 years in relation to the demand and supply (LOS Yield) balance in the SEQ Water Strategy.

This assessment does not consider the environmental, social and economic impacts of the dam operating levels in relation to flood mitigation for downstream properties and infrastructure.

2 Background

Major flooding occurred in the Brisbane River catchment on 13 January 2011.

This resulted in the Brisbane River peaking at 4.46m at the Port Office in Brisbane City and causing extensive damage to properties and businesses throughout the catchment. The 2011 flood was about 1m lower than the 1974 Flood event of 5.45m at the Port Office, Brisbane City. However, indications are that the social and economic impacts are much more significant given the building and business developments in the catchment over the last 37 years. Flood rebuilding is currently estimated to cost about \$5B.

The Minister for Natural Resources, Mines and Energy and the Minister for Trade has written to the Commissioner on 20 January 2011, requesting the Queensland Water Commission provide all necessary assistance to Seqwater in their review of the operation of Wivenhoe and Somerset Dams.

3 Role of Queensland Water Commission

3.1 Background/Context

The Queensland Water Commission (the Commission) is responsible for providing advice to the Minister on matters relating to water supply and demand management for water for SEQ. A key function of the Commission is to provide advice on the desired Levels of Service (LOS) for water supplied in SEQ.

The SEQ Water Strategy defines the LOS objectives to include the expected frequency, duration and severity of restrictions during future droughts based on a total demand of 375 litres/person/day (including residential, non-residential and system losses) of which 230 litres/person/day is attributed to residential demand. The LOS objectives are provided in Appendix A.

QWC

INFORMATION MATERIAL ONLY

The Commission also makes and administers the South East Queensland System Operating Plan (SOP) under the *Water Act 2000* which sets out the rules for operating the SEQ Water Grid to help achieve the LOS objectives.

While the LOS objectives specify the basis for operating the Grid over the long term, the risk criteria of the SOP provide the basis for balancing water security and operating costs over the short term (up to 5 years).

The SOP risk criteria are given below:

Volume of water stored by all key water grid storages	Probability of reaching 40% and 30% volume of water stored		
	within 1 year	Within 3 years	Within 5 years
40%	Less than 0.2%	Not Specified	Less than 5%
30%	Not Specified	Less than 0.5%	Less than 1%

3.2 Report to Seqwater

To support Seqwater's review of the operations of Wivenhoe and Somerset Dams, the Commission has conducted a series of modelling exercises to determine the potential impacts of certain operating arrangements on the security of supply for the region.

Consideration has been given to the ability of the SEQ Water Grid to continue to achieve the desired Level of Service objectives in the short term (up to 5 years) for various scenarios of lowering the deemed full water supply level particularly at Wivenhoe Dam, and also for Hinze and Baroon Pocket Dams.

For completeness two scenarios involving permanent reduction in the full supply volume of Wivenhoe Dam have also been considered, but further investigation is required to understand the full impacts. This assessment is based on sensitivity analysis of the total grid capacity and no detailed assessment has been undertaken.

These analyses are an exercise in assessing water security risk rather than a forecast for the future. Therefore an understanding of the consequences involved for a particular risk profile is important.

Operational and regulatory impacts such as increased pumping costs and the Water Resource Plan have not been assessed. Advice from the responsible agency or entity would need to also be considered.

This report provides an input, amongst other considerations, for Seqwater or other agencies to assist in developing advice to Government on the operating level of Wivenhoe Dam over this 2011 forecast wet season.

4 Short Term Impacts

The potential short term impacts are assessed using hydrological modelling. These are described in sections 4.1 to 4.3.

4.1 Use the SEQ Regional Water Balance Model (Wathnet Model) to assess the SOP risk criteria

The modelling conducted for this report was carried out using the Wathnet Model¹ which assesses the likelihood of reaching particular water storage volumes. Under the current operating arrangements and policies, the volumes of interest are:

- 60% of the Grid 12 volume, when full desalination production is triggered; and
- 40% of the Grid 12 volume, when full production of purified recycled water from the Western Corridor Recycled Water Project is triggered, to augment water supplies in Wivenhoe Dam and medium level restrictions would be introduced.

The Grid 12 storages and their corresponding capacities are provided in Appendix B.

Table 1 presents the five scenarios modelled. Scenarios 1 to 4 involved a reduction in water level at Wivenhoe Dam to 87%, 75%, 70% and 50% supply capacity with all other storages set at 100% full supply initially. The fifth scenario also includes a reduction of 50% capacity at Hinze and Baroon Pocket Dams with all other storages set at 100% full supply initially. This allows an assessment of the sensitivity to the security of supply should there be a need to also reduce the full operating levels in the Sunshine Coast (Baroon Pocket Dam) and Gold Coast (Hinze Dam).

For example, a 25% reduction of volume of 29,250 megalitres (ML) from Wivenhoe Dam would correspond to about 3 m drawdown from the full supply level based on the storage capacity data provided in Appendix C.

The key assumptions adopted for these runs were:

- Simulations start at the end of January 2011 with initial dam level (inflows from February 2011)
- Northern Pipeline Interconnector Stage 2 excluded
- Demand forecast as agreed by Government in late 2010 (residential consumption increasing from current levels to 200 litres/person/day by 2018)
- Medium series population growth consistent with SEQ population forecasts
- No desalination above 60% Grid 12 Storages
- Full desalination below 60% Grid 12 Storages

The scenarios do not consider day-to-day operational matters.

¹ Wathnet Model refers to the Generalised Water Supply Headworks Simulation using Network Linear Programming Model.

QWC

INFORMATION MATERIAL ONLY

Table 1: Modelled scenarios

Scenario	%reduction Wivenhoe Dam (from Full Supply)	%reduction from other dams (from Full Supply)	Volume of Water Released (ML)*	%reduction of key Grid 12 Storages (from Full Supply)
1	13*	none	150,000	7.2
2	25	none	291,250	14.0
3	30	none	349,500	16.9
4	50	none	582,500	28.1
5	50	50 (Baroon Pocket) 50 (Hinze Dam)	693,500	33.5

* Scenario 1 was selected as a starting point for the assessment of 150,000 ML (about 12.9%, but rounded up to 13% in the Table).

This is only the total volume and the strategy for release has not been considered. Operational constraints are also not considered for the purpose of this assessment.

The corresponding risk criteria results as compared to the SOP requirements are shown in Table 2.

Table 2: Results of risk criteria

Period	SOP Criteria	Scenarios (Wivenhoe/Baroon Pocket/Hinze capacities)				
		1 (87/100/100)	2 (75/100/100)	3 (70/100/100)	4 (50/100/100)	5 (50/50/50)
Probability of reaching 40% Grid 12 Storage Volume						
1 year	<0.2%	<0.01%	<0.01%	<0.01%	<0.01%	<0.01%
5 year	<5%	0.09%	0.15%	0.20%	0.31%	0.49%
Probability of reaching 30% Grid 12 Storage Volume						
3 year	<0.5%	<0.01%	<0.01%	<0.01%	<0.01%	0.01%
5 year	<1%	<0.01%	<0.01%	<0.01%	<0.01%	0.03%

From the above analysis, all scenarios 1 to 5 in Table 2 pass the SOP risk criteria. While this means that the risk associated with the short term security of supply is acceptable, the consequences of each scenario with respect to other factors would need to be examined – see Section 6.

4.2 Forecast the probability of Grid 12 storage levels over the next 5 years

To forecast the probability of the Grid 12 storages reaching a certain level, the Wathnet Model was used, based on stochastic data generation for 117 years of historical information.


Stochastically generated data provides longer time sequences of hydrologic data that have similar statistical characteristics of that of the historical record. This data provides better information about climate variability and the potential for droughts worse than have occurred on record.

Figure 1 shows the forecast storage level for the Grid 12 storages for Scenario 4 (as described in Section 4.1) with Wivenhoe drawn down to 50% and the rest of the storages at 100% at the start of the simulation in end January 2011. (Note: The plots for Scenarios 1 – 3 would show higher storage levels than those shown in Figure 1).

In this scenario:

- there is a 95% probability that the combined Grid 12 storage level remain above 60% for the next 5 years;
- there is a 99.9% probability that the combined Grid 12 storage level remains above 40% for the next 4 years; and
- there is a 50% probability that the combined Grid 12 storage level will climb back to 90% and remain at this level for the remainder of the 5 year period.

Figure 1: Scenario 4 with Wivenhoe Dam drawn down to 50% - forecast combined Grid 12 storage level showing probabilities of exceedance



QWC


INFORMATION MATERIAL ONLY

Scenario 5 (as described in Section 4.1) tests the sensitivity of the model findings by starting with Wivenhoe, Baroon Pocket and Hinze Dams all drawn down to 50% and the rest of the Grid 12 storages at 100% at the start of the simulation. This scenario represents the highest risk situation of all the modelled scenarios. The results are still within the bounds of the risk criteria set in the SOP.

In this scenario (Figure 2):

- There is almost a 95% probability that the combined Grid 12 storage level will stay above 60% for the next 5 years.
- There is at least a 95% probability (could be approaching 99.9%) that the combined Grid 12 storage level will stay above 40% for the next 5 years.
- There is a 50% probability that the combined Grid 12 storage level will climb back up to 90% and remain about this level for the next 5 years.

Figure 2: Scenario 5 with Wivenhoe, Baroon Pocket and Hinze Dams all drawn down to 50% - forecast combined Grid 12 storage level showing probabilities of exceedance



4.3 Simulated storage behaviour of Grid 12 storages over the next 6 years for three inflow scenarios (using Waspp Model)

The purpose of these simulations was to assess the potential behaviour of the Grid 12 storages over the next 6 years using three inflow scenarios based on probability of combined inflows into the storages.

For all inflow scenarios, Wivenhoe Dam was assumed to be initially at 75% capacity.

There are various methodologies that could be used for the selection of inflow sequences. For the purpose of this work, it is considered necessary to test scenarios covering a period of relative wet, of average inflow and of the driest years. The annual inflows for the Grid 12 storages from 1890 to 2007 were used in the analysis. Table 5 provides the scenarios corresponding to the 30% (wet), 50% (average) and 100% (dry) exceedance probabilities based on 6 years of cumulative inflow sequence.

The worst 6 years of inflows (100% exceedance probability) was found to correspond to the most recent drought on record from 2001 to 2006 as shown in Scenario 3 (Table 5).

Table 5: Inflow scenarios assessed

Scenario	Exceedance Probability of Inflows	Continuous Sequence (6 years)	Total Inflow Volume Grid-12 (ML)
1	30%	Jan 1985 – Dec 1990	10,193,300
2	50%	Jan 1995 – Dec 2000	7,243,300
3	100%	Jan 2001 – Dec 2006	2,752,000

The assumptions adopted in the modelling were:


- 75% initial storage volume at Wivenhoe Dam (all other storages at 100% full) - or Grid 12 storages at 86% capacity
- Demands forecast as agreed by Government in late 2010 (residential consumption increasing from current levels to 200 litres/person/day by 2018)
- Full desalination production when Grid 12 storages drop below 60% capacity, and no desalination above 60%
- Northern Pipeline Interconnector Stage 2, Hinze Dam raising and Wyaralong Dam not included
- Purified Recycled Water introduced into Wivenhoe Dam when Grid 12 storages drop below 40% capacity.

The results of the simulations for the 3 scenarios are shown in Figure 3. The worst case scenario from the historical records shows the lowest combined storage levels after June 2014, but staying above the 40% capacity to the end of 2016. Under this scenario of inflows, Purified Recycled Water is not expected to be introduced into Wivenhoe Dam within the next 5 years. For scenarios 1 and 2, the storage levels generally decreased for the first 3 years before increasing thereafter.

QWC


INFORMATION MATERIAL ONLY

Figure 3: Simulated Grid 12 storage levels for 3 inflow scenarios



The simulated storage level behaviour of Wivenhoe Dam for the three inflow scenarios is indicated in Figure 4. As expected, the simulated level for Wivenhoe Dam reduces significantly due to the worst inflow sequence. With scenarios 1 and 2, Wivenhoe Dam recovers within about 3 years.

Figure 4: Simulated Wivenhoe Dam storage levels for 3 inflow scenarios



5 Long Term Impacts - assessment of the potential impact on the LOS Yield (using Wathnet Model)

To assess the long term impacts on the LOS yield if Wivenhoe Dam was permanently operated at a reduced water supply capacity, two scenarios involving a 10% and 25% reduction from full supply level were investigated.

This assessment is carried out for completeness only and does not suggest that the dams be operated permanently with a reduced full supply level. Further investigation is necessary to understand the full impacts.

The Regional Water Security Program for SEQ establishes the desired LOS objectives which form a basis for the SEQ Water Strategy and are implemented through the SOP. These objectives provide long term security of water supply and are defined as the:

- desirable maximum frequency, duration and severity of water restrictions, and
- the average amount of water per person that must be supplied in normal times.

These objectives are used to determine the Level of Service (LOS) Yield. The LOS Yield is used, along with the projected demands, to ensure that adequate initiatives are in place to meet demand in the future.

The LOS Yield for the 2010 Infrastructure (capacity to deliver) is assessed to be 485,000 ML/a. This assumes that the desalination plant is providing 125 ML/day and Purified Recycled Water (PRW) 142 ML/day.

To assess the impact on the long term LOS Yield, the Wathnet Model was used.

This assessment was based on the following assumptions:

- 2010 infrastructure, prior to the full operation of Wyaralong Dam and Hinze Dam Stage 3
- PRW production at 52,000 ML/a (142 ML/day) and supplies 34,950 ML/a (96 ML/day) to industry
- Desalination production at 46,000 ML/a (125 ML/day)

5.1 Results – 10% reduction on Full Supply Volume for Wivenhoe Dam

The LOS Yield for the 2010 Infrastructure (capacity to deliver) is assessed to be 485,000 ML/a.


Preliminary modelling work suggests that the impact of a permanent 10% reduction in the full supply volume at Wivenhoe Dam is minimal on the LOS yield as this is within the tolerance of the model. This needs further investigation.

5.2 Results – 25% reduction on Full Supply Volume for Wivenhoe Dam

There is a significant reduction in the LOS yield of 30,000 ML/annum with a scenario where Wivenhoe Dam was permanently operated at 25% lower than the full supply level. The LOS yield has reduced from 485,000 ML/annum to 455,000 ML/annum.

Figure 5 shows that new infrastructure would need to be brought forward by about 5 years to about 2021 from 2026 under medium series population growth.

Figure 5: LOS Yield comparison



5.3 Potential for demand reduction

One of the input factors that impacts on the water supply balance is the level of extractions from the supply storages. The level of extraction depends on the level of demand in South East Queensland (SEQ).

The supply balance and risk assessment modelling conducted for this information paper includes the level of expected demand based on residential water consumption of 200 litres/person/day (l/p/d). This demand scenario is the same as the demand forecast as agreed by Government in late 2010 (residential consumption increasing from current levels to 200 l/p/d by 2018).

The 200 l/p/d demand scenario is the equivalent of total water demand of 870 ML per day for SEQ or 317,550 ML per annum.

The level of total water demand in SEQ for the last three months has been approximately 670 ML/d, which when annualised gives 244,550 ML per annum. On a per person basis this is the equivalent of 150 l/p/d. However, this level of consumption is unlikely to remain at this level.

The late 2010 demand scenario includes a residential demand at approximately 185 l/p/d for 2011, being the equivalent of 800 ML per day for SEQ or 292,000 ML per annum. If demand was to be maintained at this level, this represents a demand saving of 25,550 ML per annum.

A saving of 25,550 ML per annum (difference between 317,550 and 292,000 ML per annum) would significantly offset the LOS yield reduction of 30,000 ML/annum if Wivenhoe Dam was operated at 25% lower than Full Supply Level (FSL) over a long period (Refer to section 5.2).

6 Implications of each scenario

Table 3 provides a general framework for the assessment of the consequences of each scenario based on the following criteria for the short, intermediate and long term periods:

- Security of supply - involves examining the sufficiency, LOS Yield, desalination, and demand and supply balance
- Levers – these are some of the factors that could be reviewed to optimise the security of supply such as Levels of Service, policies and assumptions
- Inputs – these are some of the input factors which could be impacted e.g. allocation/yield, demand and supply
- Pricing – some of the scenarios may impact upon a future review of the Price Path such as through increases in operating costs.

The following observations are made and reflected in Table 3:

Short Term Reduction in Full Supply Capacity

- If releases were made as a temporary measure to reduce the water level in Wivenhoe Dam by 25% of full supply capacity (a release of about 291,250 ML), the Risk Criteria of the SEQ SOP (System Operating Plan) would still be met.
- As the volume released increases, more factors become impacted such as the increased likelihood of triggering desalination, use of purified recycled water or introduction of restrictions and potentially increased operating costs of the grid.
- The SOP Risk Criteria are satisfied for scenarios with up to 50% of water released from Wivenhoe Dam. However other factors become impacted. This assessment deals only with the volume capacity and does not consider actual availability due to operational constraints.
- Operational costs may be impacted when the storage is drawn down to 50% as the grid operating costs will increase with the need for desalination being triggered more frequently.

Long Term (Permanent) Reduction in Full Supply Capacity at Wivenhoe Dam

- A reduction of 25% in the full supply level would have an impact on the security of supply.
- New infrastructure would need to be brought forward about 5 years to meet the LOS objectives for a 25% drawdown scenario.
- There could be an impact on the future bulk water through an increase in operational costs for a 25% drawdown scenario.

There could potentially be some optimal operating arrangement, indicated as Intermediate Option in Table 3. This could involve a review of the levers such as redefining the LOS objectives based on further investigations, to ensure that the short term operating options do not compromise the long term security of supply.

QWC

INFORMATION MATERIAL ONLY

Table 3: Preliminary Framework for Consideration of Impacts on SEQ Water Strategy for Various Operating Levels of Wivenhoe Dam

Description	Base Case (status quo)	Short Term Scenario (Temporary Wivenhoe Dam drawdown)			Intermediate Option Review	Long Term Scenario (Permanent Wivenhoe Dam drawdown)	
		10%	25%	50%		² 10%	25%
Security of supply							
• Sufficiency	✓	✓	✓	✓		✓	✗
• LOS Yield	✓	✓	✓	✓		✓	✗
• Demand/ Supply Balance	✓	✓	✓	✓		✓	✗
• Desalination	✓	✓	by 2001, 2001-1 allows early potentially trigger full desalination	by 2001, 2001-1 allows early potentially trigger full desalination		✓	✗
Levers							
• Levels of Service							
• Policies							
• Assumptions							
Input							
• Allocation ¹ /Yield	✓	✓	Allocation determined by WRRP	Allocation determined by WRRP		✗ (Impacted)	✗
• Demand	✓	✓	✓	✓		✓	✗
• Supply	✓	✓	✓	✓		✗ (Impacted)	✗
Pricing							
• Impact on pricing	✓	✓	✓	✓	Review	✓	✗ new price path is potentially required

Note: ✓ Minimal Impact ✗ Impacted

¹ A permanent change in the full supply level of Wivenhoe Dam would require a review of available entitlements from Wivenhoe Dam under the Water Resource Plan.² Needs further assessment.

7 Peer review of modelling by Department of Environment and Resource Management

The results of this modelling work were reviewed by the Queensland Hydrology Group of the Department of Environment and Resource Management.

The review of the input and results for the Wathnet Model was carried out by Dr John Vitkovsky, Senior Hydrologist, who stated that: "modifications were made to the WathNet SEQ Grid model for the purposes of a sensitivity analysis of the SEQ LOS statistics from lowering the full storage volume of key large storages. There (are) a number of changes to the model that can only be done by someone with intimate knowledge of the lower-level files in the model—and cannot be made using the spreadsheet. However, as long as it is only the SEQ volume LOS statistics that are being reported on and given the modifications made to the spreadsheet the results should be reasonable." Further:

- "The model setups for all runs seem correct
- The results seem entirely reasonable and satisfy the SOP Risk Criteria
- The output statistics for both the long-term and forecast model runs seem reasonable (without re-running those scenarios) and are compliant with the LOS and SOP criteria."

For the review of the Waspp Model, Mr Craig Johansen (Principal Hydrologist) has stated that "the results of the scenarios presented for review appeared logical and appropriate based on the rules of the SEQ Water Grid and the understanding (of) the model."

Draft

Appendix A – Level of Service Objectives (SEQ Water Strategy)

- During normal operating mode, sufficient water will be available from the SEQ Water Grid to meet an average regional urban demand of 375 litres per person per day (including residential, non-residential and system losses).
- Sufficient investment in the water supply system will occur so that:
 - Medium Level Restrictions will not occur more than once every 25 years, on average
 - Medium Level Restrictions will only reduce consumption by 15 per cent below the total consumption volume in normal operating mode
 - drought response infrastructure will not be required to be built more than once every 100 years, on average
 - combined regional storage reserves do not decline to 10 per cent of capacity more than once every 1000 years, on average
 - regional water storages do not reach 5 per cent of combined storage capacity
 - Wivenhoe, Hinze and Baroon Pocket dams do not reach minimum operating levels.
- It is expected that Medium Level Restrictions will last longer than six months, no more than once every 50 years on average.

Draft

QWC

INFORMATION MATERIAL ONLY

Appendix B - Grid 12 Storages in South East Queensland

As at 27 October 2010

	FULL SUPPLY VOLUME (Megalitres)
Southern	
Little Nerang	6,705
Hinze	161,073
Total Southern	167,778
Central	
North Pine	214,302
Somerset	379,849
Wivenhoe	1,165,238
Lake Kurwongbah	14,370
Leslie Harrison	24,868
Total Central	7,798,627
Northern	
Baroon Pocket	61,000
Cooloolabin	13,800
Ewan Maddock	16,587
Lake MacDonald	8,018
Wappa	4,694
Total Northern	104,099
TOTAL SEQ	2,070,504

QWC

INFORMATION MATERIAL ONLY

Appendix C – Wivenhoe Dam Storage Capacity Data

EL (M)	AREA (HA)	VOLUME (ML)		EL (M)	AREA (HA)	VOLUME (ML)		EL (M)	AREA (HA)	VOLUME (ML)		EL (M)	AREA (HA)	VOLUME (ML)	
		TOTAL	CONV			TOTAL	CONV			TOTAL	CONV			TOTAL	CONV
82.00	22181	3555000		69.50	12355	1454257		57.00	5078	413632		44.50	1134	59185	
81.75	21916	3499905		69.25	12205	1423557		56.75	4985	401056		44.25	1095	56399	
81.50	21652	3445425		69.00	12046	1393246		56.50	4897	388705		44.00	1040	53727	
81.25	21415	3391580		68.75	11889	1363332		56.25	4810	376573		43.75	1008	51167	
81.00	21156	3338161		68.50	11723	1333815		56.00	4721	364660		43.50	977	48686	
80.75	20918	3285762		68.25	11561	1304714		55.75	4627	352873		43.25	944	46285	
80.50	20577	3233774		68.00	11401	1276013		55.50	4537	341518		43.00	911	43865	
80.25	20431	3182392		67.75	11240	1247714		55.25	4445	330291		42.75	879	41728	
80.00	20192	3131519		67.50	11080	1219815		55.00	4348	319302		42.50	828	39593	
79.75	19952	3081433		67.25	10916	1192321		54.75	4235	308561		42.25	801	37557	
79.50	19735	3031816		67.00	10751	1165238		54.50	4144	298084		42.00	774	35589	
79.25	19509	2982768		66.75	10572	1138580		54.25	4042	287851		41.75	744	33692	
79.00	19285	2934279		66.50	10389	1112378		54.00	3942	277871		41.50	715	31858	
78.75	19051	2885356		66.25	10197	1086544		53.75	3837	268147		41.25	686	30116	
78.50	18831	2839008		66.00	9990	1061414		53.50	3735	258683		41.00	659	28435	
78.25	18613	2792205		65.75	9787	1036607		53.25	3633	249474		40.75	625	26829	
78.00	18390	2745957		65.50	9586	1012440		53.00	3524	240529		40.50	599	25299	
77.75	18173	2700255		65.25	9412	988651		52.75	3425	231845		40.25	575	23834	
77.50	17956	2655099		65.00	9234	965378		52.50	3329	223403		40.00	554	22424	
77.25	17746	2610476		64.75	9058	942515		52.25	3212	215250		39.75	533	21065	
77.00	17535	2566379		64.50	8854	920089		52.00	3121	207334		39.50	512	19761	
76.75	17322	2522810		64.25	8712	898086		51.75	3028	199651		39.25	494	18504	
76.50	17118	2479767		64.00	8541	876532		51.50	2932	192203		39.00	475	17282	
76.25	16920	2437223		63.75	8371	855391		51.25	2837	184993		38.75	456	16128	
76.00	16724	2395172		63.50	8194	834691		51.00	2744	178019		38.50	437	15014	
75.75	16531	2353607		63.25	8027	814418		50.75	2654	171275		38.25	388	13937	
75.50	16337	2312526		63.00	7854	794557		50.50	2575	164730		38.00	338	11896	
75.25	16147	2271925		62.75	7710	775087		50.25	2501	158392		37.75	309	9480	
75.00	15964	2231791		62.50	7558	756014		50.00	2427	152231		37.50	279	8006	
74.75	15783	2192113		62.25	7402	737320		49.75	2350	146258		37.25	202	6725	
74.50	15612	2152874		62.00	7247	719111		49.50	2264	140494		37.00	184	5765	
74.25	15443	2114058		61.75	7093	701062		49.25	2179	134936		36.75	168	4886	
74.00	15269	2075678		61.50	6987	683435		49.00	2100	129594		36.50	153	4083	
73.75	15106	2037713		61.25	6855	666123		48.75	2029	124434		36.25	132	3379	
73.50	14943	2000156		61.00	6745	649112		48.50	1957	119452		36.00	104	2807	
73.25	14782	1963000		60.75	6629	632398		48.25	1888	114544		35.75	95	2311	
73.00	14620	1926252		60.50	6518	615965		48.00	1820	110006		35.50	84	1854	
72.75	14454	1889912		60.25	6409	599809		47.75	1754	105542		35.25	60	1507	
72.50	14286	1853992		60.00	6293	583927		47.50	1693	101235		35.00	55	1270	
72.25	14121	1818486		59.75	6180	568318		47.25	1639	97073		34.75	51	955	
72.00	13950	1783398		59.50	6085	552976		47.00	1590	93030		34.50	44	718	
71.75	13800	1748690		59.25	5975	537895		46.75	1542	89123		34.25	39	510	
71.50	13642	1714353		59.00	5876	523082		46.50	1499	85335		34.00	34	327	
71.25	13484	1680482		58.75	5775	508518		46.25	1444	81670		33.75	30	167	
71.00	13323	1646993		58.50	5574	494208		46.00	1399	78115		33.50	15	47	
70.75	13157	1613871		58.25	5573	480151		45.75	1355	74673		33.25	3	12	
70.50	13005	1581156		58.00	5467	466360		45.50	1312	71340		33.00	2	1	
70.25	12851	1548833		57.75	5371	452812		45.25	1255	68139		32.75	0	0	
70.00	12693	1516908		57.50	5273	439507		45.00	1214	65053		32.50	0	0	
69.75	12529	1485379		57.25	5175	426447		44.75	1174	62068		32.25	0	0	

Level Datum: AHD - PN 34781 EL 72.784 m
 Computed using hydrographic data produced in 1995 from 157 hydrographic
 survey records
 Full Supply Level: EL 67.000 m AHD
 River Outlet: EL 33.200 m AHD
 Containment Area: 7022.30 ha
 Latitude: 29 23 35 Longitude: 152 36 03



BRISBANE RIVER - BASIN 143
 WIVENHOE DAM 150.2 cr

STORAGE DATA

A3-110405

19/05/95