

**Nerida Jessup**

---

**From:** John Tibaldi [jtibaldi@████████████████████]  
**Sent:** Saturday, 15 January 2011 7:51 PM  
**To:** Duty Seq  
**Subject:** Strategy-Summary-Log.xls  
**Attachments:** Strategy-Summary-Log.xls

Important information: This email and any attached information is intended only for the addressee and may contain confidential and/or privileged information. If you are not the addressee, you are notified that any transmission, distribution, or other use of this information is strictly prohibited. The confidentiality attached to this email is not waived, lost or destroyed by reasons of mistaken delivery to you. If you have received this email in error please contact the sender immediately and delete the material from your email system. QLD Bulk Water Supply Authority ABN75450239876 (Trading as Seqwater).

**QFCI**      Date: 4/2/12 JM  
Exhibit Number: 1057

DATE	TIME	ACTION	CATEGORY	INITIALS
Thursday 6/1/2011	7:00 AM	<p>TM duty Engineer. Rainfall and water had been remote monitored to this point in time. TM advises Senior Duty Engineer that Flood Operations are required at both Somerset, Wivenhoe and North Pine Dams. TM arrived at FOC to assess strategies and mobilise FOC, Wivenhoe, Somerset and North Pine Dam.</p> <p><b>North Pine Dam</b> At 07:00hrs Thursday, North Pine Dam was 39.60m, 0.05m below gate trigger level and having risen 0.18m since 2/1/2011 due to a combination of base flow and runoff from rain in the last 24 hours. Given the forecast rain, gate operations will commence tonight. MBRC will be advised this morning.</p> <p><b>Somerset Dam</b> At 07:00hrs Thursday, Somerset Dam was 99.34m, 0.34m above FSL, and rising slowly. The rain in the Stanley River catchment has produced a small amount of runoff in the upper Stanley but there have been significant rises in Kilcoy Ck. Further regulator operations will be required later Thursday.</p> <p><b>Wivenhoe Dam</b> The regulator and hydro were discharging at 50 cumecs to manage baseflow recession from previous flow event. At 07:00hrs Thursday, Wivenhoe Dam was 67.31m and rising slowly. This is 0.31m above FSL and above the gate trigger level of 67.25m. There have been rises recorded at rivers and stream upstream of Wivenhoe Dam. Gates will be opened in the next 24 hours to manage the inflows from the upper Brisbane River and the outflow from Somerset.</p>	Situation Report	MT
		Strategy W1 - Various		
	8:14 AM	<p>Situation Report 0800 06/01/2011</p> <p><b>Rainfall</b> - Since 9am Wednesday, there have been widespread falls of 30mm with isolated heavy falls up to 50mm in the Somerset and Wivenhoe catchments. Totals in the North Pine catchment have generally been below 10mm. Falls up to 60mm were recorded in the Leslie Harrison catchment. - The forecast for the next 24 to 48 hours is for totals up to 150mm in SE Qld. - The catchments remain wet and are likely to generate additional runoff in the event of rain.</p> <p><b>North Pine Dam</b> - At 0700 Thursday, North Pine Dam was 39.60m, 0.05m below gate trigger level and having risen 0.18m since 2/1/2011 due to a combination of baseflow and runoff from rain in the last 24 hours. - Given the forecast rain, gate operations will commence tonight. MBRC will be advised this morning.</p> <p><b>Somerset Dam</b> - At 0700 Thursday, Somerset Dam was 99.34m, 0.34m above FSL, and rising slowly. The rain in the Stanley River catchment has produced a small amount of runoff in the upper Stanley but there have been significant rises in Kilcoy Ck. Further regulator operations will be required later Thursday.</p>	Situation Report	TM
		<p><b>Wivenhoe Dam</b> - At 0700 Thursday, Wivenhoe Dam was 67.31m and rising slowly. This is 0.31m above FSL and above the gate trigger level of 67.25m. There have been rises recorded at rivers and stream upstream of Wivenhoe Dam. Gates will be opened in the next 24 hours to manage the inflows from the upper Brisbane River and the outflow from Somerset.</p> <p><b>Impacts of Wivenhoe Dam Releases</b> - Somerset Regional, Ipswich City and Brisbane City Councils will be advised of the potential for gate operations after a full assessment of the situation this morning. At this stage it is anticipated that peak releases from Wivenhoe will be below 600m<sup>3</sup>/s but this will depend on the forecast rain and flows downstream of the dam. - The expected Wivenhoe release and local flows will at least impact upon Twin Bridges, Savages Crossing, Kholo Bridge and Colleges Crossing for several days. At this stage, there are not expected to be any adverse impacts upon Fernvale Bridge, Burtons Bridge or Mt Crosby Weir Bridge.</p> <p><b>Leslie Harrison Dam</b> Following the heavy rainfall Wednesday night, gate operations commenced at Leslie Harrison Dam late Wednesday night and are continuing. Given the forecast rainfall, gate operations are expected to continue for the next 24 to 48 hours.</p> <p>The next situation report will be issued at 1800 Thursday 6/1/2011.</p>	Situation Report	
	1:30 PM	<p>Revised Operating Strategy 1200 6/1/2011</p> <p><b>North Pine</b> - On track to open tonight</p> <p><b>Somerset/Wivenhoe</b> - No change to current status - expected inflow volume about 45,000ML. Will reach about 99.7m AHD without releases. - Expected inflow volume about 130,000ML including Somerset. Will reach about 68.3m AHD without releases. - There has been further heavy falls in the Lockyer since 0900 Thursday and the flow from the Lockyer is going to be larger than initially assessed, possibly as high as 600m<sup>3</sup>/s peaking Saturday. This may close Burtons without any contribution from Wivenhoe. The opening of the Wivenhoe gates will therefore be delayed until the Lockyer peak passes.</p>	Situation Report	TM
	2:54 PM	<p>Situation Report 1500 06/02/2011</p> <p><b>Rainfall</b> - In the 6 hours since 9am Wednesday, there have been general totals around 30mm with isolated heavy falls up to 60mm in the Somerset and Wivenhoe catchments. Totals in the North Pine catchment have generally been between 20 and 30mm. Falls between 20 and 30mm were recorded in the Leslie Harrison catchment. - The forecast for the next 24 to 48 hours is for totals up to 100mm in SE Qld. - The catchments remain wet and are likely to generate additional runoff in the event of rain.</p> <p><b>North Pine Dam</b> At 1400 Thursday, North Pine Dam was 39.66m, 0.01m above gate trigger level. Gate operations will commence at 1800 Thursday and will impact upon Youngs Crossing. MBRC have been advised and will confirm closure of Youngs Crossing prior to gate operations. Given the forecast rainfall during Friday, gate operations may continue into Saturday.</p> <p><b>Somerset Dam</b> At 0700 Thursday, Somerset Dam was 99.34m, 0.34m above FSL, and rising slowly. The rain in the Stanley River catchment has produced a small amount of runoff in the upper Stanley but there have been significant rises in Kilcoy Ck, adding to the Somerset inflows. Further regulator/sluice operations will be required in the next 24 to 48 hours. The estimated event inflow volume into Somerset Dam is 50,000ML.</p>	Situation Report	TM
		<p><b>Wivenhoe Dam</b> - At 0700 Thursday, Wivenhoe Dam was 67.31m and rising slowly. This is 0.31m above FSL and above the gate trigger level of 67.25m. There have been rises recorded at rivers and stream upstream of Wivenhoe Dam. The estimated event inflow volume into Wivenhoe Dam is 180,000ML including Somerset Dam outflow. - There has been significant rainfalls in the Lockyer Ck catchment since 0900 Thursday and a peak of about 600m<sup>3</sup>/s is expected from the Lockyer late Friday. Wivenhoe gates will be opened after flood levels in the lower Lockyer subside. At this stage Wivenhoe releases during Saturday may be as high as 1,500m<sup>3</sup>/s and continue for a couple of days.</p> <p><b>Impacts of Wivenhoe Dam Releases</b> - Somerset Regional, Ipswich City and Brisbane City Councils have been advised of the potential for gate operations during the next 24 hours. - The will at least impact upon Twin Bridges, Savages Crossing, Kholo Bridge and Colleges Crossing for several days. The relatively high Lockyer flows will at least impact upon Twin Bridges, Savages Crossing, Kholo Bridge and Colleges Crossing for several days and may impact upon Burtons Bridge early Saturday. At this stage, there are not expected to be any adverse impacts upon Fernvale Bridge or Mt Crosby Weir Bridge.</p> <p><b>Leslie Harrison Dam</b> Following the heavy rainfall Wednesday night, gate operations commenced at Leslie Harrison Dam late Wednesday night and are continuing. Given the forecast rainfall, gate operations are expected to continue for the next 24 to 48 hours.</p>	Situation Report	
7/01/11	5:33 PM	<p>Situation Report 1800 06/01/2011</p> <p><b>Rainfall</b> - In the 8 hours since 9am Wednesday, there have been general totals around 30mm with isolated heavy falls up to 60mm in the Somerset and Wivenhoe catchments. There have been significant rainfalls in the Lockyer Ck catchment in the last 24 hours with widespread falls of 50mm and isolated falls up to 75mm. Totals in the North Pine catchment have generally been about 30mm. Falls between 20 and 30mm were recorded in the Leslie Harrison catchment. - The forecast for the next 24 to 48 hours is for totals up to 100mm in SE Qld.</p> <p><b>North Pine Dam</b> At 1700 Thursday, North Pine Dam was 39.68m, 0.03m above gate trigger level. Gate operations will commence at 1800 Thursday and will impact upon Youngs Crossing. Moreton Bay Regional Council has been advised and will confirm closure of Youngs Crossing prior to gate operations. Given the forecast rainfall during Friday, gate operations may continue into Saturday.</p> <p><b>Somerset Dam</b> At 1700 Thursday, Somerset Dam was 99.45m, 0.45m above FSL, and rising slowly. The rain in the Stanley River catchment has produced a small amount of runoff in the upper Stanley but there have been significant rises in Kilcoy Ck, adding to the Somerset inflows. Further regulator/sluice operations will be required in the next 24 to 48 hours. The estimated event inflow volume into Somerset Dam is 50,000ML.</p>	Situation Report	TM



DATE	TIME	ACTION	CATEGORY	INITIALS
7/01/11		<p><b>Wivenhoe Dam</b></p> <ul style="list-style-type: none"> <li>- At 1700 Thursday, Wivenhoe Dam was 67.30m and rising slowly. This is 0.30m above FSL and above the gate trigger level of 67.25m. Upstream of the dam river levels are still rising at the Linville and Gregors Ck gauges. The estimated event inflow volume into Wivenhoe Dam is 180,000ML including Somerset Dam outflow.</li> <li>- A peak of about 600m<sup>3</sup>/s is expected from the Lockyer late Friday. At this stage there is some uncertainty associated with this estimate and it may or may not impact Burtons Bridge. Wivenhoe gates will be opened after the impact of Lockyer flows on Burtons Bridge has been ascertained and flood levels in the lower Lockyer subside. At this stage Wivenhoe releases will commence late Friday/early Saturday and may be as high as 1,500m<sup>3</sup>/s, similar to recent events, and continue for a couple of days.</li> </ul> <p><b>Impacts of Downstream of Wivenhoe</b></p> <ul style="list-style-type: none"> <li>- Somerset Regional, Ipswich City and Brisbane City Councils have been advised of the potential for gate operations during the next 24 hours.</li> <li>- The relatively high Lockyer flows will adversely impact upon Twin Bridges, Savages Crossing, Kholo Bridge and Colleges Crossing for several days and may impact upon Burtons Bridge early Saturday. At this stage, there are not expected to be any adverse impacts upon Fernvale Bridge or Mt Crosby Weir Bridge.</li> </ul> <p><b>Leslie Harrison Dam</b></p> <p>Following the heavy rainfall Wednesday night, gate operations commenced at Leslie Harrison Dam late Wednesday night and are continuing. Given the forecast rainfall, gate operations are expected to continue for the next 24 to 48 hours.</p>	Situation Report	
7/01/11	6:07 AM	<p><b>FOC Situation Report at 06:00 on Friday 7 January 2011</b></p> <p><b>Rainfall</b></p> <ul style="list-style-type: none"> <li>- There have been general totals around 30 to 50 mm with isolated heavy falls up to 75mm in the Somerset and Wivenhoe catchments since the event commenced on Wednesday 5 January 2011. There have been significant rainfalls in the Lockyer Ck catchment in the last 72 hours with widespread falls of 50mm and isolated falls up to 100mm.</li> <li>- Totals in the North Pine catchment have generally been about 35mm.</li> <li>- Falls between 20 and 30mm were recorded in the Leslie Harrison catchment.</li> <li>- The forecast for the next five days is for totals between 100 and 200mm in SE Qld. Given the saturated condition of the catchments further runoff will most likely be generated from this rainfall.</li> </ul> <p><b>North Pine Dam</b></p> <p>At 0600 Friday, North Pine Dam was at 39.48m, 0.12m below FSL. Gate operations commenced at 1915 on Thursday 6 January and are expected to continue until at least mid-day Friday 7 January when North Pine Dam is expected to be at 39.40m. These releases have impacted upon Youngs Crossing. Moreton Bay Regional Council was advised and they closed Youngs Crossing prior to gate operations commencing. Based upon the forecast rainfall, gate operations may continue into Saturday, but at this stage it is anticipated that gate operations will cease at around mid-day on Friday 7 January 2011.</p> <p><b>Somerset Dam</b></p> <ul style="list-style-type: none"> <li>- At 0600 Friday, Somerset Dam was at 99.59m, 0.59m above FSL, and rising slowly. The rain in the Stanley River catchment has produced a small amount of runoff in the Upper Stanley but there have been significant rises in Kilcoy Creek, contributing to the Somerset inflows. Somerset Dam is currently releasing at a rate of 35 cumecs and further regulator/sluice operations will be required in the next 24 to 72 hours.</li> </ul>	Situation Report	LVB
7/01/11	12:15 PM	<p><b>BitRep</b></p> <p>There has been falls between 15 and 30mm in the North Pine catchment in the last 3 hours. This will cause renew rises and increased inflows.</p>	Situation Report	TM
7/01/11	12:34 PM	<p>There are no gate movements projected for the next 3 hours.</p> <p><b>Issued Wivenhoe Directive #1</b></p> <ul style="list-style-type: none"> <li>- 15:00 Open Gate 3 from 0.0 metres to 0.5 metres</li> <li>- 16:00 Open Gate 3 from 0.5 metres to 1.0 metres</li> <li>- 17:00 Open Gate 3 from 1.0 metres to 1.5 metres</li> <li>- 18:00 Open Gate 3 from 1.5 metres to 2.0 metres</li> <li>- 19:00 Open Gate 3 from 2.0 metres to 2.5 metres</li> <li>- 20:00 Open Gate 3 from 2.5 metres to 3.0 metres</li> <li>- 21:00 Open Gate 3 from 2.5 metres to 3.5 metres</li> </ul>	Directive - Strategy W1-C	LVB
7/01/11	6:00 PM	<p><b>Situation Report 1800 Friday 07/01/2011</b></p> <p><b>Rainfall</b></p> <ul style="list-style-type: none"> <li>- Since 0900 Friday, there has been widespread 20 to 40mm throughout North Pine, Somerset and Wivenhoe catchments with isolated higher totals of 70mm in the upper reaches of the Brisbane R.</li> <li>- Advice from BoM indicates that SE Qld can expect further high rainfall totals over the next 4 days.</li> </ul> <p><b>Saturday:</b> Rain light at times 15-50mm with higher falls along the coast</p> <p><b>Sunday:</b> Widespread rain with totals between 50-100mm</p> <p><b>Monday:</b> Widespread rain again with totals between 50-100mm</p> <p><b>Tuesday:</b> Rain easing with totals between 25-50mm</p> <p>Given the saturated conditions of the catchments, significant inflows to Seqwater dams will be generated, especially following the forecast rainfall on Sunday/Monday.</p> <p><b>North Pine (Full Supply Level 39.60 m AHD)</b></p> <ul style="list-style-type: none"> <li>- At 1700 Friday, North Pine currently has 5 gates open releasing runoff from rain on Wed/Thursday. Given the very high likelihood of significant runoff during the next 4 days, gates will be kept open to match inflows over the next few days, rather than opening and closing at various times with short notice. Youngs Crossing will remain adversely impacted for the duration of the gates being open. Moreton Bay Regional Council has been advised and concurs with this strategy.</li> </ul> <p><b>Somerset (Full Supply Level 99.00 m AHD)</b></p> <ul style="list-style-type: none"> <li>- At 1700 Friday, Somerset Dam level was 100.04m AHD and rising steadily with one regulator open 100%. However, as the Wivenhoe headwater level is rising and may impact upon the operation of the regulator, this will be closed in the next few hours and a sluice gate opened. However, this strategy may need to be reviewed if significant runoff occurs in the Stanley and Upper Brisbane. Under circumstances of high inflows to</li> </ul> <p><b>Wivenhoe (Full Supply Level 67.00 m AHD)</b></p> <ul style="list-style-type: none"> <li>- At 1700 Friday, Wivenhoe Dam was 68.10 m AHD and rising steadily with one gate open to 1.5 metres and releasing about 168m<sup>3</sup>/s. River levels upstream of Wivenhoe Dam were rising again, generating further inflow to the dam. It is intended to ramp up the release from Wivenhoe to about 1,200m<sup>3</sup>/s during the next 18 hours. However, given the high likelihood of significant inflows in the next week, this may be increased later on the weekend.</li> <li>- Since the commencement of the event on 02/01/2011, approximately 140,000ML has flowed into Wivenhoe Dam with a further 160,000ML expected (including Somerset release) based on the recorded rainfall to date. Approximately 24,000ML has been released from Wivenhoe via the hydro and regulator at about 50m<sup>3</sup>/s.</li> </ul> <p><b>Impacts downstream of Wivenhoe</b></p> <ul style="list-style-type: none"> <li>- The projected Wivenhoe release of 1,200m<sup>3</sup>/s combined with Lockyer flows and local runoff will mean that all crossings downstream of Wivenhoe (Twin Bridges, Savages Crossing, Burtons Bridge, Kholo Bridge and Colleges Crossing) will be adversely impacted for several days. At this stage Fernvale and Mt Crosby Weir Bridge are not expected to be affected.</li> <li>- Discussions were held with Brisbane City Council and BoM with all agencies agreeing that the combined flow in the lower Brisbane R will only add 50mm to an upper limit of 100mm to the recorded water levels in the City Reach of the Brisbane River. However, it is noted that tides in the lower Brisbane R will be 0.4 to 0.5 metres higher than predicted tides</li> <li>- Somerset Regional, Ipswich City and Brisbane City Councils have been advised of the Wivenhoe operating strategy.</li> </ul>	Situation Report	TM
7/01/11	9:53 PM	<p><b>Issued Wivenhoe Directive #2</b></p> <ul style="list-style-type: none"> <li>- 07/01/2011 22:00 Open Gate 2 from 0.0 metres to 0.5 metres</li> <li>- 07/01/2011 23:00 Open Gate 4 from 0.0 metres to 0.5 metres</li> <li>- 08/01/2011 00:00 Open Gate 2 from 0.5 metres to 1.0 metres</li> <li>- 08/01/2011 01:00 Open Gate 4 from 0.5 metres to 1.0 metres</li> <li>- 08/01/2011 02:00 Open Gate 1 from 0.0 metres to 0.5 metres</li> <li>- 08/01/2011 03:00 Open Gate 5 from 0.0 metres to 0.5 metres</li> <li>- 08/01/2011 04:00 Open Gate 2 from 1.0 metres to 1.5 metres</li> </ul>	Directive Strategy W1-D	MT
8/01/11	4:55 AM	<p><b>Issued Wivenhoe Directive #3</b></p> <ul style="list-style-type: none"> <li>- 08/01/2011 05:00 Open Gate 4 from 1.0 metres to 1.5 metres</li> <li>- 08/01/2011 06:00 Open Gate 1 from 0.5 metres to 1.0 metres</li> <li>- 08/01/2011 07:00 Open Gate 5 from 0.5 metres to 1.0 metres</li> <li>- 08/01/2011 08:00 Open Gate 3 from 3.5 metres to 4.0 metres</li> </ul>	Directive Strategy W1-D	MT
8/01/11	8:00 AM	<p><b>Issued Wivenhoe Directive #4</b></p> <ul style="list-style-type: none"> <li>- 08/01/2011 09:00 Open Gate 2 from 1.5 metres to 2.0 metres</li> <li>- 08/01/2011 10:00 Open Gate 4 from 1.5 metres to 2.0 metres</li> <li>- 08/01/2011 11:00 Open Gate 1 from 1.0 metres to 1.5 metres</li> <li>- 08/01/2011 12:00 Open Gate 5 from 1.0 metres to 1.5 metres</li> <li>- 08/01/2011 13:00 Open Gate 2 from 2.0 metres to 2.5 metres</li> <li>- 08/01/2011 14:00 Open Gate 4 from 2.0 metres to 2.5 metres</li> </ul>	Directive Strategy W1-D	AN
8/01/11	11:30 AM	<p><b>Issued Somerset Directive #3</b></p> <ul style="list-style-type: none"> <li>- Please open Sluice M to 100% at 12:00.</li> </ul>	Directive	AN
9/01/11	12:00 AM	<p><b>Issued Wivenhoe Directive #5</b></p> <ul style="list-style-type: none"> <li>- Open Gate 3 from 4.0 metres to 4.5 metres</li> </ul>	Directive - Strategy W1-E	NGA
9/01/11	4:30 AM	<p><b>Issued Wivenhoe Directive #6</b></p> <ul style="list-style-type: none"> <li>- Open Gate 1 from 1.5 metres to 2.0 metres</li> </ul>	Directive Strategy W1-E	NGA

DATE	TIME	ACTION	CATEGORY	INITIALS
6:15 AM		<p><b>FOC Situation Report at 06:00 on Sunday 9 January 2011</b></p> <p><b>Rainfall</b> Catchment average rainfall for the past 12 hours is: North Pine Dam (less than 10 mm); Somerset Dam (40 mm); Wivenhoe Dam (less than 10 mm). The bulk of the rain that has fallen in the Somerset Dam catchment has occurred in the last two hours, with recorded falls exceeding 60mm in some areas. The BOM forecast for the next seven days issued at 0450 this morning is:-</p> <p>Sunday: Rain periods. Monday: Rain periods. Tuesday: Rain periods. Wednesday: A few showers. Thursday: A shower or two. Friday: A shower or two. Saturday: Mostly fine.</p> <p>A severe weather warning remains current for heavy rainfall in the dam catchment areas. The dam catchments are relatively saturated and significant inflows will be generated if the forecast rainfall eventuates.</p> <p><b>North Pine Dam (Full Supply Level 39.60 m AHD)</b> The dam level is currently 39.47 m AHD and steady. Two radial gates remain open to release runoff generated from recent rainfall. Based on rainfall forecasts, the radial gates have been kept open in anticipation of further inflows over the next few days. However unless significant rain falls today, consideration will be given to closing the gates late this afternoon or early tomorrow morning and discussions to finalise a decision on the timing of radial gate closure will be held with the Moreton Bay Regional Council later today. Youngs crossing will remain closed while releases are in progress.</p> <p><b>Somerset Dam (Full Supply Level 99.00 m AHD)</b> The dam level is currently falling slowly, with the current level being 100.27m AHD. However the rain that has fallen in the dam catchment over the last two hours (recorded falls exceed 60mm in some areas) will result in significant inflows later today. The current release rate into Wivenhoe Dam is 35,000ML/day. Since the commencement of the event on 02/01/2011 approximately 55,000ML has been released from the dam, with a total of at least 150,000ML to be released based on the currently recorded rainfall. The total release for the event is likely to increase significantly over the next few days based on the current rainfall forecasts. At this stage, releases will continue until at least Tuesday.</p> <p><b>Wivenhoe Dam (Full Supply Level 67.00 m AHD)</b> The dam level is currently falling slowly, with the current level being 68.56m AHD. River levels upstream of the dam are receding, however further inflows will result from any additional rainfall. The current gate operation strategy will maintain flows of around 1,600m<sup>3</sup>/s in the mid-Brisbane River. The current release rate from Wivenhoe Dam is 116,000ML/day. Since the commencement of the event on 02/01/2011 approximately 150,000ML has been released from the dam, with a total of at least 450,000ML to be released based on the currently recorded rainfall. The total release for the event is likely to increase over the next few days based on the current rainfall forecasts. At this stage, releases will continue until at least Wednesday.</p> <p><b>Impacts downstream of Wivenhoe Dam</b> - The current Wivenhoe Dam release combined with Lockyer flows and local runoff will mean that all low level crossings downstream of Wivenhoe (Twin Bridges, Savages Crossing, Burtons Bridge, Kholo Bridge and</p>	Situation Report	JT
8:15 AM		<p>Issued Somerset Directive #4. - Please open Sluice K to 100% at 09:00.</p>	Directive	NGA
10:30 AM		<p>Issued Wivenhoe Directive #7. - Open Gate 5 from 1.5 metres to 2.0 metres</p>	Directive Strategy W1-E	NGA
12:30 PM		<p>Issued Somerset Directive #5. - Please open Sluice N to 100% at 13:00 - Please open Sluice J to 100% at 14:00</p>	Directive	NGA
3:30 PM		<p><b>Strategy W2</b> Duty Engineer Conference held at the FOC. Attended by RA, JR, TM with JT on conf phone. At this stage operating at the top end of W1 and the bottom end of W2. Storing approx. 300,000 ML at present (above Wivenhoe) with an additional 500,000 ML expected to flow into the dams from rainfall on the ground. The rainfall system is currently in the N-E part of the catchment and expected to travel south over the next 24-36 hours according to the BOM forecasts. This has the potential to significantly increase flows in Lockyer Ck &amp; the Bremer River which potentially could close Fernvale Bridge and Mt Crosby Bridge and increase the risk of flooding in the Lower Brisbane. Releases from Wivenhoe Dam will be maintained at the current level of ~ 1,400 cumecs. If required, releases from Wivenhoe Dam will be reduced to contain the flow in the Mid-Brisbane to 1,600 cumecs and 3,000 cumecs in the Lower Brisbane. At this stage it is anticipated that levels below 102.5 in Somerset and 72.5 in Wivenhoe can be attained.</p>	Situation Report - Strategy W2	NGA
5:51 PM		<p><b>Situation Report 1700 Sunday 9/1/2011</b></p> <p><b>Rainfall</b> Catchment average rainfall for the past 12 hours is: North Pine Dam (60 mm); Somerset Dam (150 mm); Wivenhoe Dam (80 mm). The bulk of the rain that has fallen in the upper reaches of the Stanley and Brisbane Rivers.</p> <p>The BOM rainfall forecast for the next few days is:- Monday: Very heavy rain periods with totals up to 300mm centred around North Pine. Tuesday: Rain periods with totals up to 150mm centred around North Pine. Wednesday: A few showers less than 10mm Thursday: A shower or two. Friday: A shower or two. Saturday: Mostly fine.</p> <p>A severe weather warning remains current for heavy rainfall in the dam catchment areas. The dam catchments are relatively saturated and significant inflows will be generated if the forecast rainfall eventuates.</p> <p><b>North Pine Dam (Full Supply Level 39.60 m AHD)</b> The dam level is currently 39.65 m AHD and rising at 1600. Following the rain in the 9 hours, the number of open gates has been increased from 2 to 5 which are expected to remain open for the next 12 hours. Youngs Crossing will remain closed while releases are in progress.</p> <p><b>Somerset Dam (Full Supply Level 99.00 m AHD)</b> - The dam level is 100.75 m AHD and rising quickly. Estimated peak inflow to the dam is about 3,000m<sup>3</sup>/s. Five sluice gates are open releasing about 1,100m<sup>3</sup>/s (95,000ML/d) into Wivenhoe Dam. At this stage the dam will reach at least 101.5 during early Tuesday morning. - Since the commencement of the event on 02/01/2011 approximately 80,000ML has been released from the dam, with an event total of at least 320,000ML based on the recorded rainfall to date. The event total is expected to increase significantly due to the forecast rain in the next 24 to 48 hours. At this stage, releases will continue until at least Wednesday.</p> <p><b>Wivenhoe Dam (Full Supply Level 67.00 m AHD)</b> - The dam level is currently rising again, with the current level being 68.70m AHD. Estimated peak inflow to the dam just from the Upper Brisbane R is about 5,000m<sup>3</sup>/s and, at this stage, the dam will reach at least 72.5 m AHD during Wednesday morning. River levels upstream of the dam are rising quickly with significant inflow being generated from the intense heavy rainfall. The current gate operation strategy will maintain flows of around 1,600m<sup>3</sup>/s in the mid-Brisbane River for the next 24 hours. This may mean temporarily reducing releases from Wivenhoe Dam as Lockyer flows increase. However, releases may have to be increased significantly during Monday depending on the rain in the next 12 to 24 hours. The current release rate from Wivenhoe Dam is 1,400m<sup>3</sup>/s (120,000ML/day). - Since the commencement of the event on 02/01/2011 approximately 210,000ML has been released from the dam, with an event total approaching 1,000,000ML (including Somerset outflow) based on the recorded rainfall to date. The total release for the event is likely to increase over the next few days based on the current rainfall forecasts. At this stage, releases will continue until at least Saturday 15th January 2011.</p> <p><b>Impacts downstream of Wivenhoe Dam</b> - The current Wivenhoe Dam release combined with Lockyer flows and local runoff will mean that all low level crossings downstream of Wivenhoe (Twin Bridges, Savages Crossing, Burtons Bridge, Kholo Bridge and Cottages Crossing) will be adversely impacted until at least Saturday 15 January.</p>	Situation Report - Strategy W2	TM
7:15 PM		<p>FOC called Peter Allan advising him that FOC is now looking at much larger flows and will have to ramp up releases to around 3000 cumecs as by as early as midnight which is likely to have flooding impacts on low-lying areas of Brisbane.</p>	Correspondence - Strategy W2 - transition to W3	BS
9:04 PM		<p><b>Strategy W3</b> <b>Situation Report 2100 9/01/2011</b></p> <p><b>Rainfall</b> - Very heavy rainfall has been recorded in the upper reaches of the Brisbane and Stanley in the last 6 hours with totals up to 140mm. Totals for the last 24 hours range from 100 to 300mm. - Rainfall of similar magnitudes is expected in the 12 to 24 hours, especially around the Bremer/Warrill catchments as the system tracks south. - A severe weather warning remains current for heavy rainfall in the dam catchment areas.</p> <p><b>Somerset Dam (Full Supply Level 99.00 m AHD)</b> - The dam level is 101.68 m AHD (about 500,000ML currently in storage) and rising quickly. Peak inflow to the dam is estimated to be about 4,000 m<sup>3</sup>/s based on observed rainfall and could be as high as 5,000m<sup>3</sup>/s with additional forecast rainfall. Five sluice gates are open releasing about 1,100m<sup>3</sup>/s (95,000ML/d) into Wivenhoe Dam. At this stage the dam will reach at least 103.5 early Tuesday morning which will adversely impact areas around Kilcoy. - Since the commencement of the event on 02/01/2011 approximately 100,000ML has been released from the dam into Wivenhoe, with an event total of the order of 520,000ML expected. This may increase due to the forecast rain in the next 24 to 48 hours. At this stage, releases will continue until at least Thursday.</p>	Situation Report - Strategy W3	TM





DATE	TIME	ACTION	CATEGORY	INITIALS
2:58 PM		<p><b>FOC Situation Report at 12:00 on Monday 10 January 2011</b></p> <p><b>Rainfall</b> Significant rainfall has fallen in the Wivenhoe Dam catchment over the last 3 hours, with falls exceeding 100mm. This rainfall will significantly increase inflows into the dam. A severe weather warning remains current for heavy rainfall in the dam catchment areas. The QPF issued by BOM at 10:00 estimates rainfalls for the 24 hours to 10:00 Tuesday as North Pine Dam (75mm to 150mm); Wivenhoe/Somerses Dam Catchments (50mm - 100mm). Potentially significant rain moving towards the dam catchments is currently evident on the BOM radar.</p> <p><b>Somerses Dam (Full Supply Level 99.00 m AHD)</b> The dam level is 103.41m AHD and rising. Peak inflow to the dam is estimated to be about 4,200 m<sup>3</sup>/s. Five sluice gates are open releasing about 1,100m<sup>3</sup>/s (95,000ML/day) into Wivenhoe Dam. At this stage the dam lake level will reach about 103.5m AHD on Monday afternoon. Areas around Kilcoy will continue to be adversely affected.</p> <p><b>Wivenhoe Dam (Full Supply Level 67.00 m AHD)</b> - The dam level is 72.41m AHD and rising quickly. The rainfall experienced over the last 2 to 3 hours will result in significant further inflows into the dam and releases from the dam will need to be increased in accordance with Flood Mitigation procedures and to ensure that a fuse plug is not initiated. The initiation of a fuse plug will result in a rapid uncontrolled outflow from the dam of 2,000m<sup>3</sup>/s being added to the gate release outflow. Outflows into the Brisbane River from both Lockyer Creek and the Bremer River are also increasing. - Five radial gates are currently open at the dam releasing about 2,000m<sup>3</sup>/s into the Brisbane River and this will need to be increased steadily to an outflow of 2,800m<sup>3</sup>/s over the next 9 hours (commencing at 1500). At this stage, the dam will reach about 73.8m AHD during Tuesday morning. - The objective for dam operations is currently to minimise the impact of urban flooding in areas downstream of the dam and to keep river flows in the lower Brisbane River below 4,000m<sup>3</sup>/s if possible. This is significantly less than the current estimated combined pre-dam peak inflow of 12,000m<sup>3</sup>/s. If further rainfall occurs, dam releases may need to be increased further and this may result in river flows in the lower Brisbane River approaching or exceeding 5,000m<sup>3</sup>/s.</p> <p><b>Impacts downstream of Wivenhoe Dam</b> - The projected Wivenhoe Dam releases combined with Lockyer Creek flows and local runoff will mean that all crossings downstream of Wivenhoe (Twin Bridges, Fernvale, Savages Crossing, Burtons Bridge, Kholo Bridge, Mt Crosby Weir and Colleges Crossing) will be adversely impacted until at least Sunday 16 January in varying degrees. - Water levels in the lower Brisbane River will be impacted by the combined flows of Lockyer Creek, Bremer River, local runoff and releases from Wivenhoe Dam.</p> <p><b>Outlook</b> Heavy rainfall continues throughout South East Queensland and the situation could deteriorate rapidly over the next 24 hours. The flood operation centre will continue to monitor the situation and provide every six hours until the situation stabilizes.</p>	Situation Report - Strategy W3	TM
12:02 PM		Spoke with Peter Borrows (Seqwater) to answer elaborate on Situation Report and inform him of large rainfalls currently occurring in the Wivenhoe catchment.	Correspondence	LVB
4:00 PM		<p>Issued Wivenhoe Directive #11.</p> <ul style="list-style-type: none"> <li>• Open Gate 2 to 4.0 m at 15:00</li> <li>• Open Gate 4 to 4.0 m at 16:30</li> <li>• Open Gate 3 to 5.0 m at 16:00</li> <li>• Open Gate 1 to 3.5 m at 16:30</li> <li>• Open Gate 5 to 3.5 m at 17:00</li> <li>• Open Gate 2 to 4.5 m at 17:30</li> <li>• Open Gate 4 to 4.5 m at 18:00</li> <li>• Open Gate 1 to 4.0 m at 18:30</li> <li>• Open Gate 5 to 4.0 m at 19:00</li> <li>• Open Gate 1 to 4.5 m at 19:30</li> </ul>	Directive Strategy W3	LVB
3:15 PM		Had conference call with BoM. They agree with FOC on model discharge results. However, BoM included 6hrs of additional rain which takes the discharge to 4600m <sup>3</sup> /s	Correspondence	LVB
6:06 PM		Get weather update from BoM - the forecast now is - still more of the same of what we had today.	Other	LVB
6:43 PM		<p><b>FOC Situation Report at 18:00 on Monday 10 January 2011</b></p> <p><b>Rainfall</b> - Only minor rainfall has been experienced in the North Pine Dam and Somerses Dam catchments with a catchment averages of less than 20mm. - However, significant rain has fallen in the Wivenhoe Dam catchment over the last 9 hours, with isolated falls exceeding 100mm. This rainfall has significantly increase inflows into the dam. A severe weather warning remains current for heavy rainfall in the dam catchment areas. The QPF issued by BOM at 10:00 estimates rainfalls for the 24 hours to 10:00 Tuesday as North Pine Dam (25mm to 60mm, with isolated falls to 100mm); Wivenhoe/Somerses Dam Catchments (25mm to 50mm, with isolated falls to 100mm). Potentially significant rain moving towards the dam catchments is currently evident on the BOM radar.</p> <p><b>North Pine Dam (Full Supply Level 39.60 m AHD)</b> - The dam level is 39.84m AHD and falling slowly (storing 9,000ML above FSL). Five gates are open and releasing 362 m<sup>3</sup>/s. The inflow into the dam since the commencement of the event is 72,000 ML. Estimated event volume is 84,000 ML assuming no further rainfall. Releases from the dam will continue until at least Wednesday 12 January 2011.</p> <p><b>Somerses Dam (Full Supply Level 99.00 m AHD)</b> The dam level is 103.46m AHD and rising slowly. Peak inflow to the dam is estimated to be about 4,200 m<sup>3</sup>/s. Total discharge into Wivenhoe Dam is currently 1700m<sup>3</sup>/s and this discharge will decrease slowly in the next 24 hours to be around 1200m<sup>3</sup>/s late Tuesday. The dam level will peak at 103.5m AHD in the next few hours, unless further significant rainfall is experienced. Areas around Kilcoy will continue to be adversely affected.</p> <p><b>Wivenhoe Dam (Full Supply Level 67.00 m AHD)</b> - The dam level is 72.92m AHD and rising quickly. Releases from the dam have been increased over the last 3 hours in accordance with Flood Mitigation procedures and to ensure that a fuse plug is not initiated. The initiation of a fuse plug will result in a rapid uncontrolled outflow from the dam of 2,000m<sup>3</sup>/s being added to the gate release outflow. Outflows into the Brisbane River from both Lockyer Creek and the Bremer River are also increasing. The flash flooding experienced in the upper areas of Lockyer Creek have been examined and are not expected to significantly increase Brisbane River flows above the current projection of 4000m<sup>3</sup>/s at Mogill. - Five radial gates are currently open at the dam releasing about 2,400m<sup>3</sup>/s into the Brisbane River and this will need to be increased steadily to an outflow of 2,800m<sup>3</sup>/s. At this stage, the dam will reach about 73.8m AHD during Tuesday morning. - The objective for dam operations is currently to minimise the impact of urban flooding in areas downstream of the dam and to keep river flows in the lower Brisbane River below 4,000m<sup>3</sup>/s if possible. This is significantly less than the current estimated combined pre-dam peak inflow of 12,000m<sup>3</sup>/s. If further rainfall occurs, dam releases may need to be increased further and this may result in river flows in the lower Brisbane River approaching or exceeding 5,000m<sup>3</sup>/s.</p> <p><b>Impacts downstream of Wivenhoe Dam</b> The projected Wivenhoe Dam releases combined with Lockyer Creek flows and local runoff will mean that all crossings downstream of Wivenhoe (Twin Bridges, Fernvale, Savages Crossing, Burtons Bridge, Kholo Bridge, Mt Crosby Weir and Colleges Crossing) will be adversely impacted until at least Sunday 16 January in varying degrees. - Water levels in the lower Brisbane River will be impacted by the combined flows of Lockyer Creek, Bremer River, local runoff and releases from Wivenhoe Dam.</p> <p><b>Outlook</b> Heavy rainfall continues throughout South East Queensland and the situation could deteriorate rapidly over the next 24 hours. The flood operation centre will continue to monitor the situation and provide every six hours until the situation stabilizes.</p>	Situation Report Strategy W3	TM
20:00 PM		Peter Baddley (BoM) called to advise of situation regarding flows in Lockyer. Estimated very heavy localised rainfall (eg. 600mm in few hours) on Toowoomba escarpment to cause observed flood flooding. Will monitor via Glenore Grove gauging station.	Correspondence	JW
21:00 PM		Spoke to Peter Allan regarding strategies for reducing Wivenhoe release to mitigate latest event in Lockyer. Peter endorsed variation to manual to operate at minimum gate settings to create gap to allow peak of flash flood to pass. Also endorsed concept allowing Wivenhoe HW to rise above 74 m AHD briefly.	Correspondence	JW
20:20 PM		Spoke to Peter Baddley (BoM) regarding reducing Wivenhoe release to accommodate peak of Lockyer flash flood.	Correspondence	JW
11:20 PM		Spoke to Rob Drury to give situation update. Rob agreed that if possible to reduce flow from Wivenhoe to accommodate Lockyer flash flood peak.	Correspondence	JW
11:56 PM		<p><b>FOC Situation Report at 00:00 Tuesday 11 January 2011</b></p> <p><b>Rainfall</b> - Rainfall continues in the North Pine Dam, Somerses Dam and Wivenhoe Dam catchments with falls of generally less than 20mm since 18:00 today. However, some isolated falls in the Upper Brisbane River of up to 110 mm have been recorded at Monsdale in this time. This rainfall will increase inflows into the dam. - A severe weather warning remains current for heavy rainfall in the dam catchment areas. The QPF issued by BOM at 16:00 estimates rainfalls for the 24 hours to 10:00 Tuesday as North Pine Dam (25mm to 50mm, with isolated falls to 100mm); Wivenhoe/Somerses Dam Catchments (25mm to 50mm, with isolated falls to 100mm).</p> <p><b>North Pine Dam (Full Supply Level 39.60 m AHD)</b> The dam level is 39.80m AHD and falling slowly (storing 4,400ML above FSL). Five gates are open, releasing 153 m<sup>3</sup>/s. The inflow into the dam since the commencement of the event is 74,000 ML. Estimated event volume is 84,000 ML assuming no further rainfall. Releases from the dam will continue until at least Wednesday 12 January 2011.</p> <p><b>Somerses Dam (Full Supply Level 99.00 m AHD)</b> The dam level is 103.40m AHD and falling slowly. Peak inflow to the dam is estimated to be about 4,200 m<sup>3</sup>/s. Total discharge into Wivenhoe Dam is currently 1700m<sup>3</sup>/s and this discharge will decrease slowly in the next 24 hours to be around 1200m<sup>3</sup>/s late Tuesday. The dam level peaked at 103.52m AHD at 19:00 on Monday 10 January 2011, unless further significant rainfall is experienced. Areas around Kilcoy will continue to be adversely affected.</p>	Situation Report	RA

DATE	TIME	ACTION	CATEGORY	INITIALS
		<p><b>Wivenhoe Dam (Full Supply Level 67.00 m AHD)</b></p> <ul style="list-style-type: none"> <li>The dam level is 73.22m AHD and rising at about 50 mm/hour. Releases from the dam have been held at a rate of 2,750 m<sup>3</sup>/s since 19:30 hours. Outflows into the Brisbane River from both Lockyer Creek and the Bremer River are also increasing.</li> <li>The BoM has provided further advice about the flash flooding experienced in the upper areas of Lockyer Creek. The rainfall responsible for this event was not observed at any rainfall stations but it is considered to be very significant. Flood levels in the Lockyer Creek catchment will exceed maximum recorded levels in some stations in the upper catchment. This flow may result in increases in Brisbane River levels below the junction of Lockyer Creek.</li> <li>Five radial gates are currently open at the dam releasing about 2,750m<sup>3</sup>/s into the Brisbane River. At this stage, the dam will reach about 73.8m AHD during Tuesday afternoon.</li> <li>The objective for dam operations is currently to minimise the impact of urban flooding in areas downstream of the dam and to keep river flows in the lower Brisbane River below 4,000m<sup>3</sup>/s if possible. This is significantly less than the current estimated combined pre-dam peak inflow of 12,000m<sup>3</sup>/s. If further rainfall occurs, dam releases may need to be increased further and this may result in river flows in the lower Brisbane River approaching or exceeding 5,000m<sup>3</sup>/s.</li> </ul> <p><b>Impacts downstream of Wivenhoe Dam</b></p> <ul style="list-style-type: none"> <li>The projected Wivenhoe Dam releases combined with Lockyer Creek flows and local runoff will mean that all crossings downstream of Wivenhoe (Twin Bridges, Fernvale, Savages Crossing, Burtons Bridge, Kholo Bridge, Mt Crosby Weir and Colleges Crossing) will be adversely impacted until at least Sunday 16 January in varying degrees.</li> <li>Water levels in the lower Brisbane River will be impacted by the combined flows of Lockyer Creek, Bremer River, local runoff and releases from Wivenhoe Dam.</li> <li>The BoM will provide further information regarding the magnitude of the flash flood event occurring in Lockyer Creek early Tuesday morning. Consideration will be given to modifying the releases from Wivenhoe Dam to try to moderate the peak flows emanating from Lockyer Creek.</li> </ul> <p><b>Outlook</b></p> <p>Heavy rainfall continues throughout South East Queensland and the situation could deteriorate over the next 24 hours. The flood operation centre will continue to monitor the situation and provide situation reports every six hours until the situation stabilizes.</p>	Situation Report - Strategy W3	
11/01/11				
	4:30 AM	<p>Issued Somerset Directive #6.</p> <ul style="list-style-type: none"> <li>Please close Sluice J at 05:00</li> <li>Please close Sluice N at 06:00</li> <li>Please close Sluice K at 07:00</li> </ul>	Directive	JW
	6:15 AM	Spoke to Peter Baddeley (BoM) regarding reducing Wivenhoe release to accommodate peak of Lockyer flash flood. Update: Consensus was that reducing release from Wivenhoe would no longer be feasible due to attenuation of Lockyer peak and significant additional rainfall in upper Brisbane during the night.	Correspondence	JW
	6:12 AM	<p><b>FOC Situation Report at 06:00 on Tuesday 11 January 2011</b></p> <p><b>Basinfall</b></p> <ul style="list-style-type: none"> <li>Rainfall continues in the North Pine Dam, Somerset Dam and Wivenhoe Dam catchments. Isolated falls in the Upper Brisbane River of up to 125 mm have been recorded with widespread falls of 40 to 70 mm in the Somerset Dam catchment. This rainfall will increase inflows into the dam.</li> <li>There has also been 20 to 50 mm in the Lockyer Creek catchment in the last 12 hours with falls of up to 30 mm in the Bremer River.</li> <li>A severe weather warning remains current for heavy rainfall in the dam catchment areas. The QPF issued by BoM at 16:00 estimates rainfalls for the 24 hours to 10:00 Tuesday as North Pine Dam (25mm to 50mm, with isolated falls to 100mm); Wivenhoe/Somerset Dam Catchments (25mm to 50mm, with isolated falls to 100mm).</li> </ul> <p><b>North Pine Dam (Full Supply Level 39.60 m AHD)</b></p> <p>The dam level is 39.80m AHD and has commenced rising again (storing 4,400ML above FSL). Five gates are open releasing 177 m<sup>3</sup>/s. The inflow into the dam since the commencement of the event is 77,000 ML. Estimated event volume is 88,000 ML assuming no further rainfall. Releases from the dam will continue until at least Wednesday 12 January 2011.</p> <p><b>Somerset Dam (Full Supply Level 99.00 m AHD)</b></p> <ul style="list-style-type: none"> <li>The dam level is 103.27m AHD and falling slowly. Peak inflow to the dam is estimated to be about 4,200 m<sup>3</sup>/s. Total discharge into Wivenhoe Dam is currently 1400 m<sup>3</sup>/s and this discharge will be decreased in the next few hours to be around 500 m<sup>3</sup>/s later on Tuesday. This is to ensure that the combined flood mitigation capacity in Somerset and Wivenhoe Dam is maximized.</li> <li>The dam level peaked at 103.52m AHD at 19:00 on Monday 10 January 2011, (unless further significant rainfall is experienced). Areas around Kilcoy will continue to be adversely affected.</li> </ul>	Situation Report	
		<p><b>Wivenhoe Dam (Full Supply Level 67.00 m AHD)</b></p> <ul style="list-style-type: none"> <li>The dam level is 73.51m AHD and rising at about 25 mm/hour. Releases from the dam have been held at a rate of 2,750 m<sup>3</sup>/s since 19:30 hours on Monday 10 January 2011. Outflows into the Brisbane River from both Lockyer Creek and the Bremer River are also increasing.</li> <li>The BoM has provided further advice about the flash flooding experienced in the upper areas of Lockyer Creek. The rainfall responsible for this event was not observed at any rainfall stations but it is considered to be extreme. Flood levels in the Lockyer Creek catchment will exceed maximum recorded levels in some stations in the upper catchment. This flow will result in increases in Brisbane River levels below the junction of Lockyer Creek.</li> <li>Five radial gates are currently open at the dam releasing about 2,750m<sup>3</sup>/s into the Brisbane River. At this stage, the dam will reach just over 74.0m AHD during Tuesday evening.</li> <li>Above EL 74.0m AHD the objective for dam operations is to maintain the security of the dam and minimise downstream flood flows if possible.</li> <li>If further rainfall occurs, dam releases may need to be increased further and this may result in river flows in the lower Brisbane River approaching or exceeding 5,000m<sup>3</sup>/s.</li> </ul> <p><b>Impacts downstream of Wivenhoe Dam</b></p> <ul style="list-style-type: none"> <li>The projected Wivenhoe Dam releases combined with Lockyer Creek flows and local runoff will mean that all crossings downstream of Wivenhoe (Twin Bridges, Fernvale, Savages Crossing, Burtons Bridge, Kholo Bridge, Mt Crosby Weir and Colleges Crossing) will be adversely impacted until at least Sunday 16 January in varying degrees.</li> <li>Water levels in the lower Brisbane River will be impacted by the combined flows of Lockyer Creek, Bremer River, local runoff and releases from Wivenhoe Dam.</li> <li>The BoM will provide further information regarding the magnitude of the flash flood event occurring in Lockyer Creek early Tuesday morning. Consideration was given to modifying the releases from Wivenhoe Dam to try to moderate the peak flows emanating from Lockyer Creek but the rainfall in the past 12 hours in the catchment above the dam makes this option not possible. Therefore instead of decreasing releases to accommodate the Lockyer Creek flows, the strategy will endeavour to maintain the current releases until Lockyer Creek peaks.</li> </ul>	Situation Report - Strategy W3/W4	
	8:00 AM	<p>Issued Wivenhoe Directive #12.</p> <ul style="list-style-type: none"> <li>Open Gate 5 to 4.5 m at 08:00</li> <li>Open Gates 2 and 4 to 6.0 m at 08:30</li> <li>Open Gate 3 to 5.5 m at 09:00</li> </ul>	Directive - Strategy W3/W4	DP
	8:10 AM	JT called Peter Allen to advise of current Wivenhoe situation - Will exceed EL74m. Increasing gate opening to a minimum of 3700 m <sup>3</sup> /s and gate operations will progress. Advising transition from strategy W3 to W4	Correspondence - Strategy W3/W4	DP
	9:00 AM	<p>Issued Wivenhoe Directive #13.</p> <ul style="list-style-type: none"> <li>Open Gates 2 and 4 to 5.5 m at 09:30</li> <li>Open Gates 1 and 5 to 5.5 m at 10:00</li> <li>Open Gate 3 to 6.0 m at 10:30</li> <li>Open Gates 2 and 4 to 6.0 m at 11:00</li> <li>Open Gates 1 and 5 to 6.0 m at 11:30</li> </ul>	Directive - Strategy W3/W4	DP
	9:09 AM	JT called SEQwater maintenance (Jo Misner) advised that Wivenhoe has lost power, possibly blown high voltage fuses. JO to resolve issue.	Correspondence	DP
	9:13 AM	Energex called. All incoming power has been lost at Wivenhoe.	Correspondence	DP
	10:29 AM	Stan from SEQwater called TM. In conference with Barton Maher. Internal questioning of release strategy. Internal discussion regarding current approved strategy. Preparing a briefing note.	Correspondence	DP
	11:02 AM	Peter Borrowes (Seqwater) requested update on situation.	Correspondence	DP
	11:38 AM	JT called Peter Burrows and advised that releases at Wivenhoe will be ramped up to 4000cumecs and strategy will be revised on an hourly basis. In reality releasing slightly less than the Flood Ops manual.	Correspondence	DP
	12:00 PM	<p><b>Strategy W4A</b></p> <p>Issued Wivenhoe Directive #14.</p> <ul style="list-style-type: none"> <li>Open Gates 2, 3 and 4 to 6.5 m at 12:00</li> <li>Open Gates 1 and 5 to 6.5 m at 12:30</li> <li>Open Gate 3 to 7.0 m at 13:00</li> </ul>	Directive Strategy W4A	DP



DATE	TIME	ACTION	CATEGORY	INITIALS
	12:11 PM	<p>SRRRep 1200 11/1/2011</p> <p>Somerset/Wivenhoe</p> <ul style="list-style-type: none"> <li>Our current strategy revolves around trying to prevent initiation of the first fuse plug at EL 75.6m. If this happens we will get a rapid increase of about 2,000m<sup>3</sup>/s in outflow from the dam in addition to the gate release which could be as high as 4,500 to 5,000m<sup>3</sup>/s at the time. However, it may be that fuse plug initiation might provide a lower outflow than increasing the gate outflow to protect it. In this case, we would adopt an alternate scenario.</li> <li>Sluices have been closed at Somerset and this will result in high upstream water levels affecting Kilcoy.</li> <li>With no further rainfall, Wivenhoe will approach 75.0m AHD and there will be an attempt to limit the dam outflow to 4,500m<sup>3</sup>/s, however this strategy currently being reviewed on an hour by hour basis. The release will be 4,000m<sup>3</sup>/s by 1300.</li> <li>With 50mm rainfall in the Stanley and Upper Brisbane in the next 12 to 24 hours, the release will need to be significantly increased to be in the order 6,000m<sup>3</sup>/s.</li> <li>It should be noted that the flow in the lower Brisbane River in 1974 was about 6,500m<sup>3</sup>/s.</li> <li>Wivenhoe has lost incoming mains power and are on backup power. Energex are attempting to rectify.</li> </ul> <p>North Pine</p> <p>Inflows and outflows are increasing very rapid and will exceed 2,000m<sup>3</sup>/s.</p>	Situation Report - Strategy W4A/W4B	
	1:00 PM	Issued Wivenhoe Directive #15.	Directive Strategy W4A	DP
	1:00 PM	Open Gates 1, 2, 3, 4 and 5 to 7.0 m at 13:15	Directive Strategy W4A	DP
	1:26 PM	Peter Burrows (Seqwater) called and requested the FOC request the BoM to consider if Wivenhoe is releasing 9000cumecs.	Correspondence	DP
	1:55 PM	SEQWater is continually revising release strategy, could be as high as 6500cumecs by tonight. If dam stabilises, then estimates may be reduced. TM also passed on information for BoM to consider the effects at Brisbane if Wivenhoe releases 9000cumecs.	Situation Report Strategy W4A/W4B	DP
	2:00 PM	Issued Wivenhoe Directive #17.	Directive Strategy W4A	DP
	2:15 PM	Open Gates 1, 2, 3, 4 and 5 to 8.0 m	Directive Strategy W4A	DP
	3:14 PM	Peter Burrows (Seqwater) called to discuss the proposed release of 10,000cumecs. JT and TM explained release strategy is constantly being revised.	Correspondence	DP
	3:15 PM	Issued Wivenhoe Directive #19.	Directive Strategy W4A	DP
	3:30 PM	Open Gates 1, 2, 3, 4 and 5 to 9.5 m	Directive Strategy W4A	DP
	3:40 PM	Peter Baddley & Jimmy Stewart had a conference with JT, JR, TM and RA about current release strategy and possible maximum release scenario of 10000m <sup>3</sup> /s. This would be of a similar magnitude to the 1893 event (~8.36m in Brisbane Port Office)	Correspondence	DP
	4:15 PM	Issued Wivenhoe Directive #21.	Directive Strategy W4A	DP
	4:33 PM	Phone call with TM and Peter Burrows. Discussed that even though the magnitude flood in Brisbane is similar to 1974 flood event, the no-dam flood would be significantly larger without Wivenhoe.	Correspondence	DP
	4:41 PM	Peter Allen phone call. PA requested more technical information in the status reports released by Duty Engineers. PA will send through an example of the technical data requested in the report.	Correspondence	DP
	4:45 PM	Issued Wivenhoe Directive #22.	Directive Strategy W4A	DP
	5:15 PM	Issued Wivenhoe Directive #23.	Directive Strategy W4A	DP
	5:22 PM	Open Gates 1, 2, 3, 4 and 5 to 11.0 m	Correspondence	DP
	5:48 PM	Rob Drury asking Tarong Energy to hold off releasing water from Spiltyard Creek.	Correspondence	DP
	6:00 PM	Issued Wivenhoe Directive #24.	Directive Strategy W4A	DP
	6:00 PM	<p>Situation Report 1800 11 January 2011</p> <ul style="list-style-type: none"> <li>In the last twelve hours totals of up to 370mm have fallen in the area around Wivenhoe Dam. In the last hour, rainfalls between 15 and 30mm have been recorded in the same area. At 1800, the BoM advised that falls between 50 to 100mm are still forecast for the 24hrs to 1600 Wednesday 12 January 2011 for the North Pine and Somerset/Wivenhoe catchments.</li> <li>At 1730 Wivenhoe Dam was 74.92m AHD and rising slowly and releasing about 6,700m<sup>3</sup>/s.</li> <li>The current expectation is that the dam will reach a steady state (outflow equals inflow) within the next 3 hours without further significant rainfall. At this time, release from the dam will be about 8,000 m<sup>3</sup>/s.</li> <li>If there is no further rainfall, it may be possible to then slowly reduce this release overnight.</li> <li>The dam is expected to peak below 75.5m AHD which is 100mm below the first fuse plug initiation level.</li> <li>Note that the automatic recorder as indicated on the BoM website is affected by drawdown and is not reflecting the actual lake level and tendency.</li> <li>The Flood Operations Centre is continuing to monitor rainfalls and water levels through the Brisbane and Pine catchments and reviewing operating strategy every 30 minutes. The FOC is also maintaining close contact with warning agencies and local councils.</li> <li>The next report will be issued at 2100 12 January 2011.</li> </ul>	Situation Report Strategy W4A/W4B	TM
	6:07 PM	Recap of current release strategy amongst Duty Engineers. Current Wivenhoe scenario: 74.9 m - all gates at 12m. Won't go to 13m settings until level reaches 75.0 m AHD.	Correspondence Strategy W4A	DP
	7:30 PM	Doug Grigg (Wivenhoe Dam) called to report that Wivenhoe Level 74.97m AHD is holding.	Correspondence	AN
	8:25 PM	Joe Meisner rang to advise that the high voltage feeder to Wivenhoe will not be restored for the duration of this event. JT advised that Wivenhoe is operating successfully on the generator, and they have a fair bit of diesel. There are still 2 other backups to operate the gates.	Correspondence	AN
	8:30 PM	Doug Grigg (Wivenhoe Dam) called to advise that Wivenhoe's level is 5mm down.	Correspondence	AN
	8:30 PM	Issued Somerset Directive #7.	Directive	AN
	8:35 PM	Peter Burrows (Seqwater) called FOC to speak with all duty engineers on the operating strategies for Wivenhoe releases.	Correspondence Strategy W4A	AN
	8:55 PM	Peter Burrows (Seqwater) rang asking about possibly reducing releases. TM advised that we are seriously considering it, but this would have little effect on the levels in Brisbane River. Peter would like technical reports every hour throughout the night.	Correspondence	AN
	9:00 PM	<p>Drainage Phase</p> <p>Issued Wivenhoe Directive #25.</p> <p>Close Gates 1, 2, 3, 4 and 5 to 11.0 m</p>	Directive Drainage Phase	AN
	9:25 PM	The last directive to lower the Wivenhoe gates to 11m should have been 11.5m. A new directive to raise to 11.5m was issued.	Directive	AN
	9:30 PM	Mal Lane (North Pine Dam) called. They are still behind in gate closures.	Correspondence	AN
	9:30 PM	Issued Wivenhoe Directive #26.	Directive	AN
	9:40 PM	JW called Doug Grigg (Wivenhoe Dam) to obtain a current level. EL 74.97 Gates have been raised to 11.5m.	Correspondence	AN
	10:15 AM	<p>Issued North Pine Directive #21a.</p> <ul style="list-style-type: none"> <li>Gate B: Close to increment 4 at 22:30</li> <li>Gate D: Close to increment 4 at 22:45</li> <li>Gate A: Close to increment 4 at 23:00</li> <li>Gate E: Close to increment 4 at 23:15</li> <li>Gate C: Close to increment 4 at 23:30</li> <li>Gate B: Close to increment 3 at 23:45</li> </ul>	Directive	AN
	10:35 PM	Doug Grigg (Wivenhoe Dam) called to report lake level of 74.94m AHD @ 10:30hrs.	Correspondence	AN
	11:00 PM	Doug Grigg (Wivenhoe Dam) called to report lake level of 74.92m AHD @ 11:00hrs.	Correspondence	AN
	11:00 AM	Issued Wivenhoe Directive #27 - note directive #28 was a duplicate and not sent	Directive	AN
	12/01/11	<p>Close Gates 5, 1, 4, 2 and 3 to 10.0 m</p> <p>JW called Doug Grigg (Wivenhoe Dam) to obtain a current level. EL 74.97 Gates have been raised to 11.5m.</p> <p>Issued North Pine Directive #22.</p> <ul style="list-style-type: none"> <li>Gate D: Close to increment 3 at 00:15</li> <li>Gate A: Close to increment 3 at 00:30</li> <li>Gate E: Close to increment 3 at 00:45</li> <li>Gate C: Close to increment 3 at 01:00</li> <li>Gate B: Close to increment 2 at 01:15</li> </ul> <p>Doug Grigg (Wivenhoe Dam) called to report lake level of 74.88m AHD @ 12:30hrs.</p>	Correspondence	AN



DATE	TIME	ACTION	CATEGORY	INITIALS
1:00 AM	John Thornton (SunWater) called to provide Energec contact details; Steve, phone number [REDACTED]	Steve indicated that he didn't believe [REDACTED] Turbot St would be disconnected from power grid in the morning.	Correspondence	JW
1:15 AM	RA rang Doug Grogg (Wivenhoe Dam) advising next directive. We want to get releases down as quick as possible while still lowering lake levels. Advised that we may possibly have a communications problem in the morning if power to [REDACTED] Turbot Street is cut.		Correspondence	AN
1:15 AM	Issued Wivenhoe Directive #29: • Close Gates 5, 1, 4, 2 and 3 to 0.0 m		Directive	AN
2:00 AM	Issued North Pine Directive #23: • Gate D: Close to increment 2 at 02:15 • Gate A: Close to increment 2 at 02:30 • Gate E: Close to increment 2 at 02:45 • Gate C: Close to increment 2 at 03:00		Directive	AN
2:10 AM	James Charalambous (BCC) rang enquiring about a release strategy. Advised one will be issued at about 3:00am. Talked about the activities of the last 24 hours.		Correspondence	AN
3:10 AM	JR rang Matt Lane (NPD) and advised no changes to gate settings planned for the next hour or so.		Correspondence	AN
3:15 AM	Issued Wivenhoe Directive #30: • Close Gates 5, 1, 4, 2 and 3 to 8.0 m		Directive	AN
3:30 AM	Brett Wyatt (SEQWater Mt Crosby WTP) called enquiring about levels at Mt Crosby		Correspondence	AN
3:40 AM	RA called Chris Lahey (BOM) advising him that because inflows are not as much as earlier anticipated, the releases from Wivenhoe are less than previously suggested.		Correspondence	AN
4:05 AM	Ian Douglas, OIC of Lowood Police, rang enquiring about the Wivenhoe fuse plug. JW advised that there is no danger of the fuse plug falling, and that current releases from Wivenhoe Dam are about 4,900 cumecs.		Correspondence	AN
4:15 AM	Issued North Pine Directive #24: • Gate B: Close to increment 1 at 04:30 • Gate D: Close to increment 1 at 04:45 • Gate A: Close to increment 1 at 05:00 • Gate E: Close to increment 1 at 05:15		Directive	AN
4:30 AM	Issued Wivenhoe Directive #31: • Close Gates 5, 1, 4, 2 and 3 to 7.0 m		Directive	AN
5:30 AM	Issued Wivenhoe Directive #32: • Close Gates 5, 1, 4, 2 and 3 to 6.0 m		Directive	AN
5:30 AM	Issued Wivenhoe Directive #33: • Close Gates 5, 1, 4, 2 and 3 to 6.0 m		Directive	AN
5:49 AM	<b>Situation Report 0600 Wed 12/01/2011</b> - No significant rain has fallen over the catchments in the past twelve hours. Less than 10 to 15 millimeters of rainfall is expected over the next 24-48 hours. - Wivenhoe Dam peaked on the 11th January, Tuesday night at 19:00 at 74.97 mAHd with a corresponding discharge of 7,450 m3/s. The release have now been scaled back to 4,300m3/s at 05:00 am. Wivenhoe Dam is currently 74.77 m AHd and falling slowly. - The releases from Wivenhoe Dam will be temporarily reduced to 2,500 m3/s to allow the peak of Lockyer Creek to enter the Brisbane River, after which they will be increased to maximum of 3,500 m3/s. This release will then be maintained to drain the flood storage component within the required 7 days. - Somerset Dam is at 105.10 mAHd and slowly rising. The dam is discharging 1,230 m3/s over the spillway. The dam is expected to peak this morning near its current level. Sluice gates will be utilised to assist the draining of the flood storage compartment commencing on Thursday. - The combined flood event volume in Somerset and Wivenhoe Dams is estimated to be in excess of 2 million megalitres. - North Pine Dam is currently releasing 105 m3/s through five gates. At 17:00 the lake was 39.78 mAHd. The event has a volume of around 200,000 ML. The peak discharge from the dam was 2,800 m3/s. This is categorised as an extreme event in the order of 1 in 10,000. - The Flood Operations Centre is continuing to monitor rainfalls and water levels through the Brisbane and Pine catchments and reviewing operating strategy every 30 minutes. The FOC is also maintaining close contact with warning agencies and local councils. - The next report will be issued at 08:00 12 January 2011.	Situation Report	RA	
7:15 AM	Issued Wivenhoe Directive #34: • Close Gates 1 and 5 to 3.5 m • Close Gates 2 and 4 to 4.0 m		Directive	KH
7:57 AM	<b>Situation Report 0800 Wed 12/01/2011</b> <b>Rainfall</b> - No significant rain has fallen over the catchments in the past twelve hours. Less than 10 to 15 millimeters of rainfall is expected over the next 24-48 hours. <b>Somerset/Wivenhoe</b> - Somerset Dam has peaked at 105.11 mAHd at 06:00 on 12 January 2011 and the dam is discharging 1,230 m3/s over the spillway. Sluice gates will be utilised to assist the draining of the flood storage compartment commencing later Wednesday. - Wivenhoe Dam peaked at 74.97 mAHd at 19:00 on 11 January 2011 with a corresponding discharge of 7,450 m3/s. Wivenhoe Dam was 74.75 m AHd at 07:30 and generally falling slowly. - The releases from Wivenhoe Dam have been temporarily reduced to 2,500 m3/s at 07:30 to allow the peak of Lockyer Creek to enter the Brisbane River. After the downstream peak in the lower Brisbane River has passed, releases will be increased to maximum of 3,500 m3/s. This release will then be maintained to drain the flood storage component within the required 7 days. - The combined flood event volume in Somerset and Wivenhoe Dams is estimated to be in excess of 2 million megalitres. <b>North Pine</b> At 07:00 North Pine Dam was 39.78 mAHd falling and releasing about 105 m3/s. North Pine has peaked at 41.11 mAHd at 14:00 on 11 January 1974 with peak release of 2,800 m3/s. The event has a volume of around 200,000 ML. It is expected that gates will be close later Wednesday or early Thursday. <b>Strategy</b> - The Flood Operations Centre is continuing to monitor rainfalls and water levels through the Brisbane and Pine catchments and reviewing operating strategy every 30 minutes. The FOC is maintaining close contact with warning agencies and local councils. - The next report will be issued at 12:00 12 January 2011.	Situation Report	TM	
8:30 AM	Issued North Pine Directive #25: • Gate E: Open to increment 2 at 08:45		Directive	KH
10:15 AM	Issued Somerset Directive #8: • Fully Open Sluice L at 10:30		Directive	KH
12:55 PM	Peter Baddiley, Rob Verlessey, Jim Stevenson from BoM visited FOC to liaise with the Duty Engineers.		Correspondence	NGA
2:15 PM	Issued North Pine Directive #26: • Gate E: Close to increment 1 at 14:15		Directive	NGA
2:45 PM	Issued North Pine Directive #27: • Gate C: Close to increment 1 at 14:45		Directive	NGA
3:00 PM	<b>Situation Report 1500 Wed 12/01/2011</b> <b>Rainfall</b> Rainfall in the last 12 hours is generally below 5mm with a couple of 10mm falls in the Stanley and North Pine catchments. There is no significant rain expected for the next 4 days. <b>Somerset/Wivenhoe</b> - Somerset Dam has peaked at 105.11 mAHd at 06:00 on 12 January 2011. One sluice was opened at 10:30 12 January 2011 and the dam is discharging 1,440 m3/s. Sluice gates will be utilised to drain of the flood storage compartment during the next 5 days. - Wivenhoe Dam peaked at 74.97 mAHd at 19:00 on 11 January 2011 with a corresponding discharge of 7,450 m3/s. Wivenhoe Dam was 74.81 m AHd at 15:00 and steady. - The releases from Wivenhoe Dam have been temporarily reduced to 2,500 m3/s at 07:30 12 January 2011 to allow the peak of Lockyer Creek to enter the Brisbane River. After the downstream peak in the lower Brisbane River has passed, releases will be increased to maximum of 3,500 m3/s. This release will then be maintained to drain the flood storage component within the required 7 days. - The combined flood event volume in Somerset and Wivenhoe Dams is estimated to be in excess of 2 million megalitres. <b>North Pine</b> At 15:00 North Pine Dam was 39.74 mAHd falling with all gates open 1 increment, releasing about 80 m3/s. North Pine peaked at 41.11 mAHd at 14:00 on 11 January 1974 with peak release of 2,800 m3/s. The event has a volume of around 200,000 ML. It is expected that gates will be closed on Thursday or Thursday. <b>Strategy</b> The Flood Operations Centre is continuing to monitor rainfalls and water levels through the Brisbane and Pine catchments and reviewing operating strategy every 30 minutes. The FOC is maintaining close contact with warning agencies and local councils. The next report will be issued at 18:00 12 January 2011.	Situation Report	TM	

DATE	TIME	ACTION	CATEGORY	INITIALS
	4:20 PM	Ken Morris (BOC) called FOC and had phone conference with Duty Engrs. He was seeking update for briefing with Lord Mayor.	Correspondence	NSA
	6:00 PM	<p><b>Situation Report 1800 Wed 12/01/2011</b></p> <p><b>Rainfall</b> Rainfall in the last 12 hours is generally below 5mm with a couple of 10mm falls in the Stanloy and North Pine catchments. There is no significant rain expected in the next 4 days.</p> <p><b>Somerse/Wivenhoe</b> - Somersea Dam has peaked at 105.11 mAHD at 06:00 on 12 January 2011. One sluice was opened at 10:30 12 January 2011. Somersea Dam was 104.87 mAHD at 17:00 12 January 2011 and discharging 1,410 m<sup>3</sup>/s. Sluice gates will be utilised to drain of the flood storage compartment during the next 5 days. - Wivenhoe Dam peaked at 74.87 mAHD at 19:00 on 11 January 2011 with a corresponding discharge of 7,450 m<sup>3</sup>/s. Wivenhoe Dam was 74.82 m AHD at 17:00 and steady. - The release from Wivenhoe Dam was reduced to 2,500 m<sup>3</sup>/s at 07:30 12 January 2011 to allow the peak of Lockyer Creek to enter the Brisbane River and this release has been maintained since. After the downstream peak in the lower Brisbane River has passed, releases will be increased to maximum of 3,500 m<sup>3</sup>/s. The release is expected to commence Thursday and then be maintained at this level to drain the flood storage component within the required 7 days. The release will not result in any renewed rises at downstream locations. - The combined flood event volume in Somersea and Wivenhoe Dams is estimated to be 2.6 million megalitres.</p> <p><b>North Pine</b> At 17:00 North Pine Dam was 39.74 mAHD steady with all gates open 1 increment, releasing about 80 m<sup>3</sup>/s. North Pine peaked at 41.11 mAHD at 14:00 on 11 January 2011 with peak release of 2,800 m<sup>3</sup>/s. The event has a volume of around 200,000 ML. It is expected that gates will be closed on Thursday or Friday.</p> <p><b>Strategy</b> The Flood Operations Centre is continuing to monitor rainfalls and water levels through the Brisbane and Pine catchments and reviewing operating strategy regularly. The FOC is maintaining close contact with warning</p>	Situation Report	TM
13/01/11				
	5:43 AM	<p><b>Situation Report 0600 13 January 2011</b></p> <p><b>Rainfall</b> Rainfall in the last 12 hours is generally below 5mm with isolated falls of up to 15mm in the Stanloy, Lockyer and Pine River catchments. There is no significant rain expected in the next 4 days.</p> <p><b>Somerse/Wivenhoe</b> - Somersea Dam peaked at 105.11 mAHD at 06:00 on Wednesday 12 January 2011. The current level is 104.34 mAHD. One sluice was opened at 10:30 on 12 January 2011 and the dam is currently discharging 1,130 m<sup>3</sup>/s. Sluice gates will be utilised to drain of the flood storage compartment during the next 5 days. - Wivenhoe Dam peaked at 74.97 mAHD at 19:00 on Tuesday 11 January 2011 with a corresponding discharge of 7,450 m<sup>3</sup>/s. Wivenhoe Dam was 74.72 m AHD at 06:00 and commenced to fall slowly. - The releases from Wivenhoe Dam have been temporarily reduced to 2,500 m<sup>3</sup>/s at 07:30 on Wednesday 12 January 2011 to allow the peak of Lockyer Creek to enter the Brisbane River. The Brisbane River has peaked at the Port Office Gauge early Thursday morning. Releases from Wivenhoe Dam will be managed to achieve a target flow of around 3,500 m<sup>3</sup>/s at Moggi. This release will then be maintained to drain the flood storage component within the required 7 days. - The combined flood event volume in Somersea and Wivenhoe Dams is estimated to be in excess of 2.6 million megalitres.</p> <p><b>North Pine</b> At 05:00 North Pine Dam was 39.70 mAHD falling with all gates open 1 increment, releasing about 80 m<sup>3</sup>/s. North Pine peaked at 41.11 mAHD at 14:00 on Tuesday 11 January 2011 with peak release of 2,800 m<sup>3</sup>/s. The event has a volume of around 200,000 ML. It is expected that all gates will be closed on Friday.</p> <p><b>Strategy</b> - The Flood Operations Centre is continuing to monitor rainfalls and water levels throughout the Brisbane and Pine River catchments and reviewing operating strategy. The FOC will continue to maintain close contact with warning agencies and local councils. - The next report will be issued at 18:00 on Thursday 13 January 2011.</p>	Situation Report	RA
	12:30 PM	<p>Wivenhoe directive #35 issued</p> <ul style="list-style-type: none"> <li>Open Gate 2 from 4.0 metres to 4.5 metres at 13:00.</li> <li>Open Gate 4 from 4.0 metres to 4.5 metres at 14:00.</li> </ul>	Directive	JW
	12:30 PM	<p>Somersea directive #10 issued</p> <ul style="list-style-type: none"> <li>Fully Open Sluice K at 13:00.</li> </ul>	Directive	JW
	2:15 PM	<p>Phone call from Steve Ross, MBRC. Advice as follows:</p> <ul style="list-style-type: none"> <li>Damage to Gwynis Rd abutments</li> <li>No evacuations</li> <li>No suburban flooding</li> <li>Not aware of any over floor flooding. Pine Shire had 0.75m freeboard.</li> </ul>	Correspondence	JW
	2:30 PM	<p>Wivenhoe directive #36 issued</p> <ul style="list-style-type: none"> <li>Open Gate 1 from 3.5 metres to 4.0 metres at 15:00.</li> <li>Open Gate 5 from 3.5 metres to 4.0 metres at 16:00.</li> <li>Open Gate 1 from 4.0 metres to 4.5 metres at 17:00.</li> <li>Open Gate 5 from 4.0 metres to 4.5 metres at 18:00.</li> </ul>	Correspondence	JW
	4:45 PM	<p>Ludj (MBRC) was advised that NPD gates will be closed at 0500 Friday</p>	Correspondence	TM
	6:00 PM	<p>Wivenhoe directive #37 issued</p> <ul style="list-style-type: none"> <li>Open Gate 2 from 4.5 metres to 5.0 metres at 18:30.</li> <li>Open Gate 4 from 4.5 metres to 5.0 metres at 19:00.</li> <li>Open Gate 1 from 4.5 metres to 5.0 metres at 19:20.</li> <li>Open Gate 5 from 4.5 metres to 5.0 metres at 20:00.</li> <li>Open Gate 3 from 5.0 metres to 5.5 metres at 20:30.</li> </ul>	Directive	JW
	7:51 PM	<p>Rob called Mal Lane (North Pine Dam) to discuss the current drainage strategy to close all gates by 5am tomorrow. Water level in North Pine Dam will be frequently monitored against the predictive model results, and gate opening will be adjusted accordingly if required.</p>	Correspondence	DP
	8:15 PM	<p>Wivenhoe directive #38 issued</p> <ul style="list-style-type: none"> <li>Open Gate 2 from 5.0 metres to 5.5 metres at 21:00.</li> <li>Open Gate 4 from 5.0 metres to 5.5 metres at 22:00.</li> <li>Open Gate 1 from 5.0 metres to 5.5 metres at 23:00.</li> <li>Open Gate 5 from 5.0 metres to 5.5 metres at 20:00.</li> <li>Open Gate 3 from 5.5 metres to 6.0 metres at 01:00 on 14/1/11</li> <li>Open Gate 3 from 5.5 metres to 6.0 metres at 02:00</li> <li>Open Gate 3 from 6.0 metres to 6.0 metres at 03:00</li> </ul>	Directive	DP
	8:28 PM	<p>Somersea directive #11 issued</p> <ul style="list-style-type: none"> <li>Fully Open Sluice N at 21:00.</li> </ul>	Directive	DP
14/01/11				
	2:10 AM	<p>Rob Ayre called Shane Watson to advise commencement of shut down of gates in accordance with Directive #30. Please undertake the following gate operations commencing at 03:15 on Friday 14 January 2011.</p> <p>The interval between gate operations is to be 15 minutes.</p> <ul style="list-style-type: none"> <li>Gate A: Close to 1 increment at 03:15</li> <li>Gate E: Close to 1 increment at 03:30</li> <li>Gate C: Close to 1 increment at 03:45</li> <li>Fully Close Gate B at 04:00</li> <li>Fully Close Gate D at 04:15</li> <li>Fully Close Gate A at 04:30</li> <li>Fully Close Gate E at 04:45</li> <li>Fully Close Gate C at 05:00</li> </ul>	Directive	DP
	5:13 AM	<p>Fax received from North Pine Dam confirming closure of all gates.</p>	Correspondence	DP
	5:15 AM	<p>Rob Ayre called MBRC to advise that North Pine Dam has closed the final gate at 5am.</p>	Correspondence	DP
	6:16 AM	<p>Malcom from North Pine Dam called to confirm that all gates are closed, and Young's Crossing should be passable within 2 hours. Lake Kurungbah level is 20.43 m.</p>	Correspondence	DP



